Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Application No. .....

Permit No. .....

(1) OWNER: Name C. GRAY Address 406 101 AVE E. EVERETT WN

(2) LOCATION OF WELL: County ISLAND — NW ¼ SE ¼ Sec 32 T. 32 N., R. 1 E. W.M.

Bearing and distance from section or subdivision corner (1223' W & 852 N OF SE ¼ COR - SEC. 32)

(3) PROPOSED USE: Domestic ☑ Industrial ☐ Municipal ☐ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) 1

New well ☑ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☑ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 303 ft. Depth of completed well 303 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6 " Diam. from 0 ft. to 293½ ft.
Threaded ☐ " Diam. from ft. to ft.
Welded ☑ " Diam. from ft. to ft.

Perforations: Yes ☐ No ☑
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes ☑ No ☐
Manufacturer's Name Johnson
Type WELDED STAINLESS Model No.
Diam. 6 Slot size 5 from 293 ft. to 303 ft.
Diam. Slot size from ft. to ft.

Gravel packed: Yes ☐ No ☑ Size of gravel:
Gravel placed from ft. to ft.

Surface seal: Yes ☑ No ☐ To what depth? 18 ft.
Material used in seal BENTO
Did any strata contain unusable water? Yes ☐ No ☑
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name
Type: H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level (180) ft.
Static level 191 ft. below top of well Date 1979
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☐ No ☑ If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test
Bailer test 20 gal./min. with ft. drawdown after 4 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes ☐ No ☑

(10) WELL LOG:

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
GRAVEL	0	55
SAND & GRAVEL	55	80
SAND	80	154
SANDY CLAY	154	190
HARD PAN	190	230
GRAVELY CLAY	230	242
WATER GRAVEL	242	245
SANDY CLAY	245	286
FINE WATER SAND	286	303
20 G.P.M. +		

Work started Mar, 19 Completed Mar, 1979

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WHIDBEY WELL DRILL (Person, firm, or corporation) (Type or print)

Address OAK HARBOR WN

[Signed] (Well Driller)

License No. 129 Date Mar, 1985

(USE ADDITIONAL SHEETS IF NECESSARY)

ECY 050-1-20