File Original and Fi Copy w h
Department of Ecolc y
Second Copy — Own 's Copy
Third Copy — Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Application No. .....

Permit No. .....

(1) OWNER: Name Fields Water assn - Fus. Address PO Box 504 Stanwood Wn.

(2) LOCATION OF WELL: County Island. SE ¼ SE ¼ Sec. 27 T. 32 N., R. 2E W.M.

Bearing and distance from section or subdivision corner 70' N & 30' E of Tract 4 - Above section.

(3) PROPOSED USE: Domestic ☐ Industrial ☐ Municipal ☐ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) ....
New well ☐ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☐ Driven ☐
Reconditioned ☐ Rotary ☒ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled ..... ft. Depth of completed well 280 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6 " Diam. from 42 ft. to 274 ft.
Threaded ☒ ..... " Diam. from ..... ft. to ..... ft.
Welded ☐ ..... " Diam. from ..... ft. to ..... ft.

Perforations: Yes ☐ No ☒
Type of perforator used .....
SIZE of perforations ..... in. by ..... in.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.

Screens: Yes ☒ No ☐
Manufacturer's Name Johnson
Type 6" Slot Size Model No. .....
Diam. 6" Slot size 10 from 274 ft. to 277 ft.
Diam. 6" Slot size 14 from 272 ft. to 280 ft.

Gravel packed: Yes ☐ No ☒ Size of gravel: .....
Gravel placed from ..... ft. to ..... ft.

Surface seal: Yes ☒ No ☐ To what depth? 20 ft.
Material used in seal Puddling Clay
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? ..... Depth of strata .....
Method of sealing strata off .....

(7) PUMP: Manufacturer's Name .....
Type: ..... H.P. .....

(8) WATER LEVELS: Land surface elevation above mean sea level 340 ft.
Static level 280 ft. below top of well Date 7-18-80
Artesian pressure ..... lbs. per square inch Date .....
Artesian water is controlled by ..... (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☒ No ☐ If yes, by whom? CWD
Yield: 20 gal./min. with 29 ft. drawdown after 4 hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level
~~000~~	~~[illegible]~~	~~000~~	~~[illegible]~~	~~[illegible]~~	
000	249				
001	220				

Date of test 7-19-80
Bailer test ..... gal./min. with ..... ft. drawdown after ..... hrs.
Artesian flow ..... g.p.m. Date .....
Temperature of water ..... Was a chemical analysis made? Yes ☐ No ☐

(10) WELL LOG:

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Hardpan & gravel	0	21
Gravel	21	63
Sand & gravel	63	7[illegible]
Clay Tan & gravel	70	11[illegible]
Clay Tan	111	2[illegible]
Gravel	250	[illegible]
Blue Clay	262	[illegible]
Sand & gravel with water	272	2[illegible]

Work started 7-10, 1980 Completed 7-15, 1980

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Camano Well Drilling (Person, firm, or corporation) (Type or print)

Address 215 N. Goodrich Rd

[Signed] Joseph Nunes (Well Driller)

License No. 0611 Date 7-25, 1980

(USE ADDITIONAL SHEETS IF NECESSARY)

ECY 050-1-20