File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Start Card No. ____
UNIQUE WELL I.D. # ____
Water Right Permit No. ____

(1) OWNER: Name Marilyn Hammond Address 1143 S. R. 532 Camano Is. WA. 98292

(2) LOCATION OF WELL: County Island ____ 1/4 ____ 1/4 Sec ____ T ____ N., R. ____ W.M.

(2a) STREET ADDRESS OF WELL (or nearest address) ____

(3) PROPOSED USE: [X] Domestic [ ] Irrigation [ ] DeWater Industrial [ ] Test Well [ ] Municipal [ ] Other [ ]

(4) TYPE OF WORK: Owner's number of well (if more than one) ____
Abandoned [ ] New well [X] Deepened [ ] Reconditioned [ ]
Method: Dug [ ] Cable [X] Rotary [ ] Bored [ ] Driven [ ] Jetted [ ]

(5) DIMENSIONS: Diameter of well 6 inches
Drilled 165 feet. Depth of completed well ____ ft.

(6) CONSTRUCTION DETAILS:
Casing Installed: 6" Diam. from +1 ft. to 161-6 ft.
Welded [X] ____" Diam. from ____ ft. to ____ ft.
Liner installed [ ] ____" Diam. from ____ ft. to ____ ft.
Threaded [ ]

Perforations: Yes [ ] No [X]
Type of perforator used ____
SIZE of perforations ____ in. by ____ in.
____ perforations from ____ ft. to ____ ft.
____ perforations from ____ ft. to ____ ft.
____ perforations from ____ ft. to ____ ft.

Screens: Yes [X] No [ ]
Manufacturer's Name Smith
Type Stainless Model No. ____
Diam. 5 Slot size 20 from 160 ft. to 165 ft.
Diam. ____ Slot size ____ from ____ ft. to ____ ft.

Gravel packed: Yes [ ] No [X] Size of gravel ____
Gravel placed from ____ ft. to ____ ft.

Surface seal: Yes [ ] No [ ] To what depth? 15 ft.
Material used in seal Bentonite
Did any strata contain unusable water? Yes [ ] No [X]
Type of water? ____ Depth of strata ____
Method of sealing strata off ____

(7) PUMP: Manufacturer's Name N/A
Type: ____ H.P. ____

(8) WATER LEVELS: Land-surface elevation above mean sea level 135 APPROX. ft.
Static level 13.4 ft. below top of well Date 12/15/86
Artesian pressure ____ lbs. per square inch Date ____
Artesian water is controlled by ____ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes [ ] No [X] If yes, by whom? ____
Yield ____ gal./min. with ____ ft. drawdown after ____ hrs.
" " " "
" " " "
Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test ____
Bailer test 20 gal./min. with 5 ft. drawdown after 24 hrs.
Airtest ____ gal./min. with stem set at ____ ft. for ____ hrs.
Artesian flow ____ g.p.m. Date ____
Temperature of water ____ Was a chemical analysis made? Yes [ ] No [X]

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
brown Clay	0	15
hardpan	15	45
Sand	45	135
compact gravel + water	135	165

Work Started 12/8/86, 19 Completed 12/15/86, 19

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME Kounkel Well Drilling (PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)
Address 7911 N. Smith Rd Camano Is. WA.
(Signed) Larry Kounkel (WELL DRILLER) License No. 1892
Contractor's Registration No. KOUNKWD099KT Date 12/23/94, 19

(USE ADDITIONAL SHEETS IF NECESSARY)

ECY 050-1-20 (2/93)