33/02-35K 6940

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Application No

Permit No

(1) OWNER: Name B.J. SUSE Address 2560 E. STRAWBERRY PT. Rd 98277

(2) LOCATION OF WELL: County ISLAND — NW¼ SE¼ Sec 35 T 33 N., R 2E W.M.

Bearing and distance from section or subdivision corner

(3) PROPOSED USE: Domestic [X] Industrial [ ] Municipal [ ] Irrigation [ ] Test Well [ ] Other [ ]

(4) TYPE OF WORK: Owner's number of well (if more than one)

New well [X] Deepened [ ] Reconditioned [ ]

Method: Dug [ ] Bored [ ] Cable [X] Driven [ ] Rotary [ ] Jetted [ ]

(5) DIMENSIONS: Diameter of well 6 inches.

Drilled 149 ft. Depth of completed well 149 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6 " Diam. from 0 ft. to 144½ ft.

Threaded [ ] " Diam. from ft. to ft.

Welded [X] " Diam. from ft. to ft.

Perforations: Yes [ ] No [X]

Type of perforator used

SIZE of perforations in. by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

Screens: Yes [X] No [ ]

Manufacturer's Name Johnson

Type STAINLESS Model No

Diam 6 Slot size 18 from 144 ft. to 149 ft.

Diam. Slot size from ft. to ft.

Gravel packed: Yes [ ] No [X] Size of gravel

Gravel placed from ft. to ft.

Surface seal: Yes [X] No [ ] To what depth? 18 ft.

Material used in seal CLAY

Did any strata contain unusable water? Yes [ ] No [X]

Type of water? Depth of strata

Method of sealing strata off

(7) PUMP: Manufacturer's Name

Type: Sub H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level 185 ft.

Static level 100 – ft. below top of well Date May 88

Artesian pressure lbs. per square inch Date

Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes [ ] No [X] If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test

Bailer test [ ] gal./min. with 36 ft. drawdown after 4 hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? Yes [ ] No [X]

(10) WELL LOG:

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
GRAVELY	0	7
HARD PAN	7	15
GRAVELY	15	48
CLAY	48	80
HARD PAN	80	138
FINE SOUPY SAND	138	144
WATER SAND MIX	144	149

Work started 19 Completed MAY 1988

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WHIDBEY DRILLERS (Person, firm, or corporation) (Type or print)

Address OAK HARBOR 98277

[Signed] [illegible] (Well Driller)

License No. 129 Date MAY 1981

(USE ADDITIONAL SHEETS IF NECESSARY)