File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Application No. G1-23506 / 33/01-27

Permit No. ....

(1) OWNER: Name Suburban Hills Address Oak Harbor

(2) LOCATION OF WELL: County ISLAND — SE ¼ SE ¼ Sec 27 T 33 N., R 1E W.M.

Bearing and distance from section or subdivision corner ~~110' West SE corner NE/4 NE/4 SE/4 SE/4 of said section~~

(3) PROPOSED USE: Domestic ☐ Industrial ☐ Municipal ☐ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) ....

New well ☑ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☑ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 208 ft. Depth of completed well 208 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6 " Diam. from 0 ft. to 198'4" ft.
Threaded ☐ " Diam. from ft. to ft.
Welded ☑ " Diam. from ft. to ft.

Perforations: Yes ☐ No ☑
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes ☑ No ☐
Manufacturer's Name Johnson
Type STAINLESS Model No. Sas
Diam. 6 Slot size 10 from 198 ft. to 208 ft.
Diam. Slot size from ft. to ft.

Gravel packed: Yes ☐ No ☑ Size of gravel:
Gravel placed from ft. to ft.

Surface seal: Yes ☑ No ☐ To what depth? 18 ft.
Material used in seal BENTONITE
Did any strata contain unusable water? Yes ☐ No ☑
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name
Type: Sub H.P. 3

(8) WATER LEVELS: Land-surface elevation above mean sea level .... 190 ft.
Static level 175 ft. below top of well Date
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☐ No ☐ If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test
Bailer test 50 gal./min. with MAX ft. drawdown after 6 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes ☐ No ☐

(10) WELL LOG: (900' N & 110' W OF SE COR)

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
HARD PAN	0	34
GRAVEL DRY	34	107
SANDY CLAY	107	120
SAND & CLAY LAYERS	120	150
CLAY with SMALL SAND STREAKS	150	181
WATER SAND	181	208
HARD CLAY	208	

Work started SEPT, 1979 Completed OCT 10, 1979

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WHIDBEY WELL DRILLERS (Person, firm, or corporation) (Type or print)

Address OAK HARBOR WN.

[Signed] Dennis Jones (Well Driller)

License No. 129 Date Oct 24, 1979

(USE ADDITIONAL SHEETS IF NECESSARY)

ECY 050-1-20