33/02-26 F

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT
STATE OF WASHINGTON

Application No. .....
~~Permit~~ Cert No. (G1-00103)

(1) OWNER: Name DAVIS LANDING OWNERS ASSOC Address 3082 N MT. BAKER CIRCLE - OAK HARBOR W

(2) LOCATION OF WELL: County ISLAND — SE ¼ NW ¼ Sec. 26 T. 33 N., R. 2 W.M.

Bearing and distance from section or subdivision corner (400' N. OF SEC 26 CENTER (LOT 16 OF DAVIS LANDING PLAT) & 850' WEST)

(3) PROPOSED USE: Domestic ☐ Industrial ☐ Municipal ☑ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) 3
New well ☑ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☑ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 148½ ft. Depth of completed well 148½ ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6" Diam. from 0 ft. to 143½ ft.
Threaded ☐ ____" Diam. from ____ ft. to ____ ft.
Welded ☑ ____" Diam. from ____ ft. to ____ ft.

Perforations: Yes ☐ No ☑
Type of perforator used ____
SIZE of perforations ____ in. by ____ in.
____ perforations from ____ ft. to ____ ft.
____ perforations from ____ ft. to ____ ft.
____ perforations from ____ ft. to ____ ft.

Screens: Yes ☑ No ☐
Manufacturer's Name Johnson
Type STAINLESS Model No. 304
Diam. 6 Slot size 10 from 143½ ft. to 148½ ft.
Diam. ____ Slot size ____ from ____ ft. to ____ ft.

Gravel packed: Yes ☐ No ☑ Size of gravel: ____
Gravel placed from ____ ft. to ____ ft.

Surface seal: Yes ☑ No ☐ To what depth? 20+ ft.
Material used in seal BENTONITE
Did any strata contain unusable water? Yes ☐ No ☑
Type of water? ____ Depth of strata ____
Method of sealing strata off ____

(7) PUMP: Manufacturer's Name Goulds
Type: Sub H.P. 1

(8) WATER LEVELS: Land-surface elevation above mean sea level ____ ft.
Static level 127 ft. below top of well Date June 79
Artesian pressure ____ lbs. per square inch Date ____
Artesian water is controlled by ____ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☐ No ☐ If yes, by whom? ____
Yield: ____ gal./min. with ____ ft. drawdown after ____ hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test ____
Bailer test 14 gal./min. with 14 ft. drawdown after 4 hrs.
Artesian flow ____ g.p.m. Date ____
Temperature of water ____ Was a chemical analysis made? Yes ☐ No ☐

(10) WELL LOG:

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
CLAY	0	8
SANDY CLAY	8	20
DRY SAND	20	33
CLAY	33	38
DIRTY DRY SAND	38	93
SAND	93	127
WATER SAND	127	148
CLAY	148+	

Work started June 10, 1979 Completed June 13, 1979

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WHIDBEY DRILLERS (Person, firm, or corporation) (Type or print)

Address OAK HARBOR WASH

[Signed] [signature] (Well Driller)

License No. 129 Date June 13, 1979

RECEIVED JUL 0 1979 DEPT. OF ECOLOGY

(USE ADDITIONAL SHEETS IF NECESSARY)

ECY 050-1-20