Note: Carbon paper not nec... forms are impregnated with chemical which automatically reproduces the w... on each underlying copy.

TYLOR RD. 33/2E/19J

33/02-19S

ile Original and First Copy with
e Division of Water Management
econd Copy — Owner's Copy
hird Copy — Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Application No. G1-21372-P

Permit No. ....

(1) OWNER: Name Taylor Rd Comm. assoc. Address

(2) LOCATION OF WELL: County Island NE¼ SE¼ Sec. 19 T. 33 N., R. 2E W.M.

Bearing and distance from section or subdivision corner 580'S & 400'W of E¼ cor.

(3) PROPOSED USE: Domestic ☒ Industrial ☐ Municipal ☒ Irrigation ☐ Test Well ☐ Other ☐

17 homes

(4) TYPE OF WORK: Owner's number of well (if more than one)....

New well ☒ Deepened ☐ Reconditioned ☐

Method: Dug ☐ Bored ☐ Cable ☐ Driven ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diam... of well 6 inches.

Drilled 243 ft. Depth of ...pleted well 243 ft.

(6) CONSTRUCTION DETAILS

Casing installed: 6 " Diam... 0 ft. to 238 ft.

Threaded ☐ " Diam... ft. to ft.

Welded ☐ " Diam... ft. to ft.

Perforations: Yes ☐ No ☒

Type of perforator used

SIZE of perforations in. by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

Screens: Yes ☒ No ☐

Manufacturer's Name C...

Type Brass Model No.

Diam. 6" Slot size 14 ... 238 ft. to 243 ft.

Diam. Slot size ... ft. to ft.

Gravel packed: Yes ☐ No ☒ Size of gravel:

Gravel placed from ft. to ft.

Surface seal: Yes ☐ No ☒ To what depth? ft.

Material used in seal

Did any strata contain unusable water? Yes ☐ No ☐

Type of water? Depth of strata

Method of sealing strata off

(7) PUMP: Manufacturer's Name Goulds

Type: Sub HP 7½

(8) WATER LEVELS: Land-surface elevation above mean sea level ≈300 ft.

Static level 215' 3" ft. below top of well Date July 71

Artesian pressure lbs. per square inch Date

Artesian water is controlled by (cap, valve, etc.)

(9) WELL TESTS: Drawdown is measured from water level lowered below level

Was a pump test made? Yes ☒ No ☐ If yes, by whom? Bebs Pump

Yield: 40 gal./min. with 24 ft. drawdown after 8 hrs.

" " "

" " "

Recovery data (time taken as zero when pump turned off; measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test

Bailer test 20 gal./min. with 10½ ft. drawdown after 1 hrs.

Artesian flow g.p.m.

Temperature of water Was a chemical analysis made? Yes ☐ No ☒

(10) WELL LOG:

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
HARD PAN	4	71
GRAVEL (CONTAINED LITTLE SAND)	71	167
FINE WATER SAND	167	182
CLAY BROWN TURNING GRAY	182	224
SANDY CLAY	224	230
WATER SAND Good	230	243
WATER SAND FINER	244	

Work started June 16, 1971. Completed July 2, 1972

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Whidbey Drillers (Person, firm, or corporation) (Type or print)

Address RT 2 Bx 494 OAK HARBOR WN

[Signed] [illegible] (Well Driller)

License No. 223 02/09/15 Date Oct 30, 1972