File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

33/01-13R
Application No.

Permit No.

(1) OWNER: Name Krieg Const Co Address 70 W. Sleeper Rd 98277

(2) LOCATION OF WELL: County ISLAND — SE ¼ SE ¼ Sec. 13 T 33 N., R 1 E W.M.

Bearing and distance from section or subdivision corner

(3) PROPOSED USE: Domestic ☐ Industrial ☐ Municipal ☐ Irrigation ☐ Test Well ☒ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) # - 2 -

New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☒ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 176 ft. Depth of completed well 176 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6 " Diam. from 0 ft. to 166½ ft.
Threaded ☐ " Diam. from ft. to ft.
Welded ☒ " Diam. from ft. to ft.

Perforations: Yes ☐ No ☒
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes ☒ No ☐
Manufacturer's Name Johnson
Type STAINLESS Model No.
Diam 6 Slot size 15 from 166 ft. to 171 ft.
Diam 6 Slot size 20 from 171 ft. to 176 ft.

Gravel packed: Yes ☐ No ☒ Size of gravel:
Gravel placed from ft. to ft.

Surface seal: Yes ☒ No ☐ To what depth? 18 ft.
Material used in seal Clay
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name
Type: Sub H.P. 5

(8) WATER LEVELS: Land-surface elevation above mean sea level 150 + ft.
Static level 136 ½ ft. below top of well Date MAY 87
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☐ No ☐ If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test
Bailer test 20 gal./min. with 10 - ft. drawdown after 4 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes ☐ No ☒

(10) WELL LOG:

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Gravel	0'	11'
Gravely Hard	11'	21'
Sand & Gravel	21'	60
Water in Fine Sand	60'	76'
~~Sand~~ - Clay Mix Fine Sand	76'	151'
Water Gravel Mix	151'	176
Clay	176'	-

50 + G.P.M.

RECEIVED
MAY 21 1987
DEPARTMENT OF ECOLOGY
NORTHWEST REGION

Work started MAY, 19 87. Completed MAY 11, 19 87

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WHIDBEY WELL DRILLERS (Person, firm, or corporation) (Type or print)

Address OAK HARBOR WASH

[Signed] Dennis Faber (Well Driller)

License No. 129 Date MAY, 19 87

(USE ADDITIONAL SHEETS IF NECESSARY)

ECY 050-1-20