The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

OK

WATER WELL REPORT
STATE OF WASHINGTON

~~Application No~~ [illegible]
Permit No G1-22705F

(1) OWNER: Name R.P. FAKKEMA Address 4086 400 AVE OAK HARBOR

(2) LOCATION OF WELL: County ISLAND SW¼ NE¼ Sec 7 T 33 N, R 2E W.M.
Bearing and distance from section or subdivision corner 1423' W & 410' N of E¼ COR - SEC. 7.

(3) PROPOSED USE: Domestic ☑ Industrial ☐ Municipal ☑ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) 2
New well ☑ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☑ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS Diameter of well 6 inches
Drilled 249 ft Depth of completed well 249 ft

(6) CONSTRUCTION DETAILS.
Casing installed: 6 " Diam from 0 ft to 240' 6" ft
Threaded ☐ " Diam from ft to ft
Welded ☑ " Diam from ft to ft

Perforations. Yes ☐ No ☑
Type of perforator used
SIZE of perforations in by in
perforations from ft to ft
perforations from ft to ft
perforations from ft to ft

Screens Yes ☑ No ☐
Manufacturer's Name Johnson
Type WIRE STAINLESS Model No 304
Diam 6 Slot size 12 from 240 ft to 244 ft
Diam 6 Slot size 18 from 244 ft to 249 ft

Gravel packed: Yes ☐ No ☑ Size of gravel
Gravel placed from ft to ft

Surface seal Yes ☑ No ☐ To what depth? 20+ ft
Material used in seal CLAY
Did any strata contain unusable water? Yes ☐ No ☑
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP Manufacturer's Name STA-RITE Design Series 40
Type Submersible H.P. 3

(8) WATER LEVELS. Land-surface elevation above mean sea level 200 ? ft
Static level 175 ft. below top of well Date JUNE 16
Artesian pressure lbs per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☑ No ☐ If yes by whom? BOB'S PUMPS
Yield 35 gal/min with 8.17 ft drawdown after 4 hrs
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level
0 min	183' 2"	2 min	174' 8"		
1/2 min	176' 2"				
1 min	174' 6"				

Date of test
Bailer test 20 gal/min with ft drawdown after 4 hrs
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes ☐ No ☐

(10) WELL LOG:
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation

MATERIAL	FROM	TO
GRAVELY	0	5
HARD PAN	5	10
SAND HARD PAN	10	33
SAND	33	85
Dirty SAND	85	102
DRY SAND	102	108
DRY GRAVEL	108	156
SANDY CLAY (GREY)	156	22
Dirty SAND	226	231
JUNKY FINE WATER SAND	231	233
Good WATER SAND	233	249
CLAY	249	

40 gal min plus

CEDARHEARTH WATER SYSTEM PWS 96889 SRC 01
ISLAND Long 122 599367 Lat 48 363336
Well Tag AGA551

Work started JUNE, 1976 Completed JUNE, 1977

WELL DRILLER'S STATEMENT.
This well was drilled under my jurisdiction and this report true to the best of my knowledge and belief

NAME WHIDBEY WELL DRILLER (Person firm or corporation) (Type or print)
Address OAK HARBOR WN
[Signed] Dennis Faber (Well Driller)
License No 0129 Date JUNE, 1977

(USE ADDITIONAL SHEETS IF NECESSARY)

S F No 7356—OS—(Rev 4-71)

WASHINGTON STATE DEPARTMENT OF ECOLOGY

Well Tagging Form

Unique Well Tag No: AGA551 S01

RECORD VERIFICATION (check one)

- [ ] Well Report available *(please attach this form to the well report and submit it to the Ecology Regional Office near you)*
- [ ] Verification inconclusive
- [ ] Well Report not available

WELL OWNERSHIP, IF DIFFERENT FROM WELL REPORT

First Name CEDAR HEARTH (968890) Last Name

Street Address

City State

LOCATION OF WELL, IF DIFFERENT FROM WELL REPORT

Well Address QUARTER HORSE RD (NO #, DEAD END ST)

City County

T N R WM Sec 1/4 of the

FOR AGENCY USE ONLY

Latitude

Longitude

- [ ] GPS
- [ ] Topographic Map
- [ ] Survey
- [ ] Computer generated

Elevation at land surface feet/meters *(circle one)*

- [ ] Digital Altimeter
- [ ] Topographic Map
- [ ] Other

Additional information, if available

- [ ] Location marked on topographic map *(please attach)*
- [ ] Location marked on air photo *(please attach)*

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

FOR AGENCY USE ONLY

WELL CHARACTERISTICS

al Description of well (size of casing type of well housing etc.)

7' CONCRETE HOLDING TANK WITH LARGE WELL HOUSE CLOSE BY (NORTH) WHICH

PAINTED RED WITH WHITE TRIM 6" CASING, WOODEN STRUCTURE

on or Well identification Tag

ELL CASING

upplemental tag needed for ease of identifying well? ☐ Yes ☒ No

where was tag placed? _____

C	B	A
F	G	H
L	K	J
P	Q	R

Scale 1 24 000 (1 "=2,000)

Indicate the location of the well within the Section by drawing a dot at that point

SECTION _____

ENTS

FOR ECOLOGY WATER RESOURCES PROGRAM ONLY

ght # _____ Date Issued _____

ne Application Permit Certificate Claim Exempt