PLEASE RETURN

33/01-118

...d First Copy with
...of Ecology
...y — Owner's Copy
...y — Driller's Copy

WATER WELL REPOR

STATE OF WASHINGTON

Application No. G1-24154
Permit No. ....

(1) OWNER: Name NORTHGATE TERRACE Address 4394 N. NORTHGATE DRIVE

(2) LOCATION OF WELL: County (150' E & 700' S - N 1/4 COR SEC. 11) ¼ NW ¼ NE Sec. 11 T. 23 N. 2 W

Bearing and distance from section or subdivision corner 150' PARK PL & 150' PARK DR. ANACORTES

(3) PROPOSED USE: Domestic ☐ Industrial ☐ Municipal ☑ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) 3
New well ☑ Deepened ☐ Reconditioned ☐
Method: Dug ☐ Cable ☑ Rotary ☐ Bored ☐ Driven ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 232 ft. Depth of completed well 232 ft.

(6) CONSTRUCTION DETAILS:
Casing installed: 6 " Diam. from 0 ft. to 222 ft.
Threaded ☐ " Diam. from ft. to ft.
Welded ☑ " Diam. from ft. to ft.

Perforations: Yes ☐ No ☑
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes ☑ No ☐
Manufacturer's Name Johnson
Type Water Strainer Model No. 304
Diam. 6 Slot size 18 from 222 ft. to 227 ft.
Diam. 6 Slot size 20 from 227 ft. to 232 ft.

Gravel packed: Yes ☐ No ☑ Size of gravel:
Gravel placed from ft. to ft.

Surface seal: Yes ☑ No ☐ To what depth? 18+ ft.
Material used in seal BENTONITE
Did any strata contain unusable water? Yes ☐ No ☑
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name
Type: H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level 225 ft.
Static level 178 ft. below top of well Date 9-28-71
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☐ No ☐ If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test
Bailer test 30 gal./min. with 15 ft. drawdown after 6 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes ☐ No ☐

(10) WELL LOG:
Formation: Describe by color, character, size of material and structure, show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of ...

MATERIAL	FROM	TO
GRAVELY HARD PAN	0	38
GRAY GRAVEL - SAND MIX	38	49
SANDY CLAY	49	84
DRY SAND	84	119
SANDY GRAY CLAY	119	138
CLAY (STICKY) GRAY	138	184
CLAY WITH SAND	184	218
WATER GRAVEL - SAND MIX	218	232
BETTER WATER GRAVEL	232	232 +
(STILL IN GRAVEL LAYER)		

Work started OCT 2 Completed OCT 8

RECEIVED
OCT 2 1971
DEPARTMENT OF ECOLOGY

WELL DRILLER'S STATEMENT:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WHIDBEY DRILLERS (Person, firm, or corporation) (Type or print)
Address OAK HARBOR
[Signed] (Well Driller)
License No. 129 Date

(USE ADDITIONAL SHEETS IF NECESSARY)