3/13/10 P

WATER WELL REPORT
STATE OF WASHINGTON

Start Card No. 207904
Water Right Permit No.

(1) OWNER: Name MABANA SHORES Address 16016 A VILLAGE GREEN DR MILL CREEK, WA 98012-

(2) LOCATION OF WELL: County SNOHOMISH - SE 1/4 SW 1/4 Sec 10 T 30 N., R 3E WM

(2a) STREET ADDRESS OF WELL (or nearest address) RED WING RD

(3) PROPOSED USE: TEST WELL

(4) TYPE OF WORK: Owner's Number of well (If more than one) 6
NEW WELL Method: ROTARY

(5) DIMENSIONS: Diameter of well 6 inches
Drilled 116 ft. Depth of completed well 111 ft.

(6) CONSTRUCTION DETAILS:
Casing installed: 6 " Dia. from +2 ft. to 100 ft.
WELDED " Dia. from ft. to ft.
" Dia. from ft. to ft.

Perforations: NO
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: YES
Manufacturer's Name JOHNSON
Type Chanel Pack Model No.
Diam. 6 slot size 10-20 from 100 ft. to 105.5 ft.
Diam. 6 slot size 20-40 from 105.5 ft. to 111 ft.

Gravel packed: NO Size of gravel
Gravel placed from ft. to ft.

Surface seal: YES To what depth? 18 ft.
Material used in seal BENTONITE
Did any strata contain unusable water? NO
Type of water? Depth of strata ft.
Method of sealing strata off

(7) PUMP: Manufacturer's Name
Type H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level ... ft.
Static level 86 ft. below top of well Date 01/13/93
Artesian Pressure lbs. per square inch Date
Artesian water controlled by

(10) WELL LOG

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change in formation.

RECEIVED
JAN - 4 1993
DEPT. OF ECOLOGY

MATERIAL	FROM	TO
TOPSOIL	0	1
BROWN SAND & GRAVEL	1	76
BROWN SAND	76	90
BROWN SAND BROWN CLAY & WATER	90	105
GRAY CLAY	105	106
GRAY SILT CLAY & WATER	106	

Work started 12/23/92 Completed 01/13/93

(9) WELL TESTS: Drawdown is amount water level is lowered below static level.
Was a pump test made? NO If yes, by whom?
Yield: gal./min with ft. drawdown after hrs.

Recover. data
Time Water Level Time Water Level Time Water Level

Date of test / /
Bailer test 2 gal/min. 12 ft. drawdown after 1.5 hrs.
Air test gal/min. w/ stem set at ft. for hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? NO

WELL CONSTRUCTOR CERTIFICATION:
I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME HAYES DRILLING, INC.
(Person, firm, or corporation) (Type or print)

ADDRESS 556 ERSHIG RD. BOW, WA

(SIGNED) [signature] License No. 1825

Contractor's Registration No. HAYESDI106J5 Date 01.15.93

2910