ENTERED

WATER WELL REPORT

STATE OF WASHINGTON

Start Card No. W103986
Unique Well I.D. #
Water Right Permit No.

(1) OWNER: Name WPC INC Address P O BOX 1728 GIG HARBOR, WA 98335- 31-1-12M

(2) LOCATION OF WELL: County ISLAND - NW 1/4 SW 1/4 Sec 12 T 31 N., R 1 WM
(2a) STREET ADDRESS OF WELL (or nearest address) ELECTRONIC COMBAT TRAINER, OAK HARBOR

(3) PROPOSED USE: OTHER

(4) TYPE OF WORK: Owner's Number of well (If more than one)
NEW WELL Method: ROTARY

(5) DIMENSIONS: Diameter of well 6 inches
Drilled 178 ft. Depth of completed well 178 ft.

(6) CONSTRUCTION DETAILS:
Casing installed: 6 " Dia. from +2 ft. to 173 ft.
WELDED " Dia. from ft. to ft.
" Dia. from ft. to ft.

Perforations: NO
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: YES
Manufacturer's Name JOHNSON
Type STAINLESS STEEL Model No.
Diam. 6 slot size 16 from 173 ft. to 178 ft.
Diam. slot size from ft. to ft.

Gravel packed: NO Size of gravel
Gravel placed from ft. to ft.

Surface seal: YES To what depth? 18 ft.
Material used in seal BENTONITE
Did any strata contain unusable water? NO
Type of water? Depth of strata ft.
Method of sealing strata off

(7) PUMP: Manufacturer's Name
Type H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level ... ft.
Static level 131 ft. below top of well Date 08/11/98
Artesian Pressure lbs. per square inch Date
Artesian water controlled by

(10) WELL LOG

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change in formation.

MATERIAL	FROM	TO
FINE GRAVEL	0	.6
DARK BROWN CLAY	.6	2
BROWN SAND & SOME GRAVEL	2	110
BROWN SANDY CLAY & SOME GRAVEL	110	125
GRAVEL SANDY BROWN CLAY	125	133
SAND GRAVEL & SOME BRN CLAY	133	140
LOOSE BRN FINE SAND & SOME GRAVEL	140	165
& WATER	140	165
LOOSE GRAY SAND GRAVEL	165	180
& WATER	165	180
LOOSE SAND WOOD	180	
& WATER	180	

RECEIVED
AUG 28 1998
NWRO-WR
DEPT OF ECOLOGY

Work started 08/10/98 Completed 08/11/98

(9) WELL TESTS: Drawdown is amount water level is lowered below static level.
Was a pump test made? If yes, by whom?
Yield: gal./min with ft. drawdown after hrs.

Recovery data
Time Water Level Time Water Level Time Water Level

Date of test / /
Bailer test gal/min. ft. drawdown after hrs.
Air test 30 gal/min. w/ stem set at 171 ft. for 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made?

WELL CONSTRUCTOR CERTIFICATION:
I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME DAHLMAN PUMP & WELL DRILL
(Person, firm, or corporation) (Type or print)

ADDRESS PO BOX 422

[SIGNED] Ralph W. [illegible] License No. 2043

Contractor's Registration No. DAHLMPW123LC Date 08/11/98