...e Original and First Copy with
...epartment of Ecology
...econd Copy — Owner's Copy
...hird Copy — Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Application No. _____

Permit No. _____

Massey Well #1

(1) OWNER: Name [illegible] Address _____

(2) LOCATION OF WELL: County [illegible] — ___ ¼ ___ ¼ Sec. 34 T. 33 N., R. 2E W.M.

Bearing and distance from section or subdivision corner

(3) PROPOSED USE: Domestic ☐ Industrial ☐ Municipal ☑ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) _____

New well ☑ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☑ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 8 inches.
Drilled 333 ft. Depth of completed well 333 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 8" Diam. from 0 ft. to 334 ft.
Threaded ☐ ___" Diam. from ___ ft. to ___ ft.
Welded ☐ ___" Diam. from ___ ft. to ___ ft.

Perforations: Yes ☐ No ☑
Type of perforator used _____
SIZE of perforations ___ in. by ___ in.
___ perforations from ___ ft. to ___ ft.
___ perforations from ___ ft. to ___ ft.
___ perforations from ___ ft. to ___ ft.

Screens: Yes ☑ No ☐
Manufacturer's Name Johnson
Type STAINLESS Model No. [illegible]
Diam. 8 Slot size 16 from 323 ft. to 3[illegible] ft.
Diam. 8 Slot size 14 from 322 ft. to 333 ft.

Gravel packed: Yes ☐ No ☑ Size of gravel: [illegible]
Gravel placed from ___ ft. to ___ ft.

Surface seal: Yes ☑ No ☐ To what depth? 20 ft.
Material used in seal CEMENT
Did any strata contain unusable water? Yes ☐ No ☑
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(7) PUMP: Manufacturer's Name _____
Type: SUB H.P. _____

(8) WATER LEVELS: Land-surface elevation above mean sea level ___ ft.
Static level 253 ft. below top of well Date July 77
Artesian pressure ___ lbs. per square inch Date _____
Artesian water is controlled by _____ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level [illegible]
Was a pump test made? Yes ☑ No ☐ If yes, by whom? _____
Yield: ___ gal./min. with ___ ft. drawdown after ___ hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test _____
Bailer test ___ gal./min. with ___ ft. drawdown after ___ hrs.
Artesian flow ___ g.p.m. Date _____
Temperature of water ___ Was a chemical analysis made? Yes ☐ No ☐

(10) WELL LOG:

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
HARD PAN	0	12
SANDY HARD	12	25
DIRTY SAND	25	51
SANDY CLAY	51	56
DIRTY SAND	56	70
CLAY	70	91
SANDY CLAY	91	100
DIRTY SAND	100	104
SANDY HARD	104	119
GRAVEL	119	200
SAND DRY	200	223
GRAVEL	223	229
DIRTY SAND	229	240
SANDY CLAY	234	240
GRAVELY HARD	240	246
SAND	246	268
CLAY	268	278
SANDY CLAY	278	292
DIRTY WATER SAND	292	300
WATER SAND (GOOD)	300	333

Work started June, 1977 Completed July, 19[illegible]

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WHIDBEY DRILLERS (Person, firm, or corporation) (Type or print)

Address OAK HARBOR WASH.

[Signed] [illegible] (Well Driller)

License No. [illegible] Date July, 1977

(USE ADDITIONAL SHEETS IF NECESSARY)

ECY 050-1-20

Enclosure 4