(261)

7AX

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT
STATE OF WASHINGTON

Application No. 29/03-22 #

Permit No.

(1) OWNER: Name W B WATER WORKS Address P.O. BOX 55 FREELAND WA 98249

(2) LOCATION OF WELL: County ISLAND — SE¼ NE¼ Sec. 22 T. 29 N., R. 3E W.M.

Bearing and distance from section or subdivision corner 1850 SOUTH 1142 WEST / NE CORNER SEC 22

(3) PROPOSED USE: Domestic ☒ Industrial ☐ Municipal ☐ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one)
New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☒ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 170 ft. Depth of completed well 170 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6" Diam. from 0 ft. to 1 ft.
Threaded ☐ " Diam. from ft. to ft.
Welded ☒ " Diam. from ft. to ft.

Perforations: Yes ☐ No ☒
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes ☒ No ☐
Manufacturer's Name COCK
Type SS Model No.
Diam. 6 Slot size 12 from 165 ft. to 170 ft.
Diam. Slot size from ft. to ft.

Gravel packed: Yes ☐ No ☒ Size of gravel:
Gravel placed from ft. to ft.

Surface seal: Yes ☒ No ☐ To what depth? 22 ft.
Material used in seal
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name
Type: H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level 380 ft.
Static level 138 ft. below top of well Date 2-78
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☒ No ☐ If yes, by whom? DRILLER
Yield: 15 gal./min. with 5 ft. drawdown after 4 hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes ☒ No ☐

4759151222358 02

(10) WELL LOG:

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP Soil	0	2
Sand Brown	2	23
Hard pan	23	56
Sand & Clay Brown	56	82
Sand Brown	82	145
Sand Med. w w	145	170
Sand Fine	170	???

Work started 2-1, 1975 Completed 2-12, 1975

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME D & W Drilling (Person, firm, or corporation) (Type or print)

Address PO Box 55 Freeland 98249

[Signed] [signature] (Well Driller)

License No. 0263 Date 11-15, 1975

(USE ADDITIONAL SHEETS IF NECESSARY)