(1) OWNER: Name VALKERIE ENTERPRISES Address 3017 W 94TH SEATTLE, WA

(2) LOCATION OF WELL: County ISLAND - 1/4 1/4 Sec 22 T 29 N., R 3E WM
(2a) STREET ADDRESS OF WELL (or nearest address) 3 MILES NORTH CLINTON

(3) PROPOSED USE: DOMESTIC

(4) TYPE OF WORK: Owner's Number of well (If more than one)
NEW WELL Method: CABLE

(5) DIMENSIONS: Diameter of well 6 inches
Drilled 191 ft. Depth of completed well 190 ft.

(6) CONSTRUCTION DETAILS:
Casing installed: 6 " Dia. from +2 ft. to 190 ft.
WELDED " Dia. from ft. to ft.
" Dia. from ft. to ft.

Perforations: NO
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: YES
Manufacturer's Name JOHNSON
Type STAINLESS STEEL Model No. X0
Diam. 6 slot size 14 from 186 ft. to 190 ft.
Diam. slot size from ft. to ft.

Gravel packed: NO Size of gravel
Gravel placed from ft. to ft.

Surface seal: NO To what depth? ft.
Material used in seal
Did any strata contain unusable water? NO
Type of water? Depth of strata ft.
Method of sealing strata off

(7) PUMP: Manufacturer's Name
Type H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level ... ft.
Static level 163 ft. below top of well Date 07/00/71
Artesian Pressure lbs. per square inch Date
Artesian water controlled by

(9) WELL TESTS: Drawdown is amount water level is lowered below static level.
Was a pump test made? NO If yes, by whom?
Yield: gal./min with ft. drawdown after hrs.

Recovery data

Time	Water Level	Time	Water Level	Time	Water Level

Date of test / /
Bailer test 12 gal/min. 13 ft. drawdown after 1 hrs.
Air test gal/min. w/ stem set at ft. for hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? NO

(10) WELL LOG

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change in formation.

MATERIAL	FROM	TO
BROWN SAND & GRAVEL	0	2
TAN CLAY & SAND & GRAVEL	2	44
GRAVEL - SEEPAGE	44	45
TAN CLAY & SAND & GRAVEL	45	58
GRAY SAND	58	162
BROWN SILT & SAND & WATER	162	186
GRAY SAND & WATER	186	

Work started 07/00/71 Completed 07/00/71

WELL CONSTRUCTOR CERTIFICATION:
I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME HAYES DRILLING, INC.
(Person, firm, or corporation) (Type or print)

ADDRESS 556 ERSHIG RD. BOW, WA

[SIGNED] _____ License No. 178

Contractor's Registration No. HAYESDI106J5 Date 11/06/92

2769