FREELAND WATER DIST.
WELL #2

...al and First Copy with ...ent of Ecology
... Copy — Owner's Copy
... Copy — Driller's Copy

WATER WELL REPORT
STATE OF WASHINGTON

RECEIVED JUL 05 1991 DEPT. OF ECOLOGY

Application No. .....
Permit No. .....

(1) OWNER: Name H. W. STONEBRIDGE Address P.O. BOX 88 FREELAND WASH.

(2) LOCATION OF WELL: County ISLAND — NW ¼ NW ¼ SEC. 14 T. 29 N., R. 2E W.M.

Bearing and distance from section or subdivision corner 1250' EAST AND 1200' South of N.W. CORNER SEC. 14

(3) PROPOSED USE: Domestic ☐ Industrial ☐ Municipal ☒ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) ....
New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☐ Driven ☐
Reconditioned ☐ Rotary ☒ Jetted ☐

(5) DIMENSIONS: Diameter of well 8" inches
Drilled 200' ft. Depth of completed well 200' ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 8" Diam. from 0 ft. to 200 ft.
Threaded ☐ ____" Diam. from ____ ft. to ____ ft.
Welded ☒ ____" Diam. from ____ ft. to ____ ft.

Perforations: Yes ☐ No ☒
Type of perforator used ____
SIZE of perforations ____ in. by ____ in.
____ perforations from ____ ft. to ____ ft.
____ perforations from ____ ft. to ____ ft.
____ perforations from ____ ft. to ____ ft.

Screens: Yes ☒ No ☐
Manufacturer's Name COOK
Type STAINLESS STEEL Model No. ____
Diam. 8" Slot size 16 from 185 ft. to 200 ft.
Diam. ____ Slot size ____ from ____ ft. to ____ ft.

Gravel packed: Yes ☐ No ☒ Size of gravel: ____
Gravel placed from ____ ft. to ____ ft.

Surface seal: Yes ☒ No ☐ To what depth? 20' ft.
Material used in seal BENTONITE
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? ____ Depth of strata ____
Method of sealing strata off ____

(7) PUMP: Manufacturer's Name NONE
Type: ____ H.P. ____

(8) WATER LEVELS: Land-surface elevation above mean sea level 200' ft.
Static level 164' ft. below top of well Date 12/4/80
Artesian pressure ____ lbs. per square inch Date ____
Artesian water is controlled by ____ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☒ No ☐ If yes, by whom? Driller
Yield: 42 gal./min. with 3'1" ft. drawdown after 4 hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test ____
Bailer test ____ gal./min. with ____ ft. drawdown after ____ hrs.
Artesian flow ____ g.p.m. Date ____
Temperature of water ____ Was a chemical analysis made? Yes ☒ No ☐

(10) WELL LOG:

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
CLAY + SAND BROWN	0'	5'
CLAY GRAY	5'	50'
SAND GRAY	50'	65'
CLAY BLUE GRAY	65'	94'
SAND BROWN	94'	160'
SAND W.W.	160'	200'

Work started 11/24, 1980 Completed 12/3, 1980

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME B + W WELL DRILLING CO. (Person, firm, or corporation) (Type or print)

Address P.O. BOX 55 FREELAND WA. 98249

[Signed] [signature] (Well Driller)

License No. 264 Date 12/4, 1982

27/02-17 D

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Application No. G1-24199

Permit No. .....

(1) OWNER: Name H. W. STONEBRIDGE Address P.O. BOX 88 FREELAND, WASH.

(2) LOCATION OF WELL: County ISLAND — NW ¼ NW ¼ Sec. 14 T. 29 N., R. 2E W.M.

Bearing and distance from section or subdivision corner 1250' EAST AND 1200' South of N.W. CORNER SEC. 14

(3) PROPOSED USE: Domestic ☐ Industrial ☐ Municipal ☒ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) ....

New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☐ Driven ☐
Reconditioned ☐ Rotary ☒ Jetted ☐

(5) DIMENSIONS: Diameter of well 8" inches.
Drilled 200' ft. Depth of completed well 200' ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 8" Diam. from 0 ft. to 200' ft.
Threaded ☐ ..." Diam. from ... ft. to ... ft.
Welded ☒ ..." Diam. from ... ft. to ... ft.

Perforations: Yes ☐ No ☒
Type of perforator used ....
SIZE of perforations ... in. by ... in.
... perforations from ... ft. to ... ft.
... perforations from ... ft. to ... ft.
... perforations from ... ft. to ... ft.

Screens: Yes ☒ No ☐
Manufacturer's Name COOK
Type STAINLESS STEEL Model No. ....
Diam. 8" Slot size 10 from 185 ft. to 200 ft.
Diam. ... Slot size ... from ... ft. to ... ft.

Gravel packed: Yes ☐ No ☒ Size of gravel: ....
Gravel placed from ... ft. to ... ft.

Surface seal: Yes ☒ No ☐ To what depth? 20' ft.
Material used in seal BENTONITE
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? .... Depth of strata ....
Method of sealing strata off ....

(7) PUMP: Manufacturer's Name NONE
Type: .... H.P. ....

(8) WATER LEVELS: Land-surface elevation above mean sea level .... 200' ft.
Static level 164' ft. below top of well Date 12/4/80
Artesian pressure ... lbs. per square inch Date ....
Artesian water is controlled by .... (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☒ No ☐ If yes, by whom? Driller
Yield: 42 gal./min. with 3'1" ft. drawdown after 4 hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test ....
Bailer test ... gal./min. with ... ft. drawdown after ... hrs.
Artesian flow ... g.p.m. Date ....
Temperature of water .... Was a chemical analysis made? Yes ☒ No ☐

(10) WELL LOG:

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
CLAY + SAND BROWN	0'	5'
CLAY GRAY	5'	50'
SAND GRAY	50'	65'
CLAY BLUE GRAY	65'	94'
SAND BROWN	94'	160'
SAND W.W.	160'	200'

Work started 11/24, 19 80 Completed 12/3, 19 80

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME B + W WELL DRILLING Co. (Person, firm, or corporation) (Type or print)

Address P.O. BOX 55 FREELAND WA. 98249

[Signed] [illegible] (Well Driller)

License No. 264 Date 12/4, 19 80

(USE ADDITIONAL SHEETS IF NECESSARY)

ECY 050-1-20