3679 ENTERED

STATE OF WASHINGTON

(1) OWNER: Name NELSON, HENRY Address 16820 194TH AVE NE WOODINVILLE, WA 98072- 29/2/5-L

(2) LOCATION OF WELL: County: ISLAND - NE 1/4 SW 1/4 Sec 5 T 29 N R 2 WM

(2a) STREET ADDRESS OF WELL (or nearest address): BUSH POINT RD

(3) PROPOSED USE: DOMESTIC (10) WELL LOG

(4) TYPE OF WORK: Owner's number of well (if more than one) NEW WELL

Method: ROTARY

(5) DIMENSIONS: Diameter of well 6 inches

Total depth 242 ft. Depth of completed well 240 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6 Dia. from +2.5 ft to 236 ft

WELDED Dia from ft to ft

Dia from ft to ft

Perforations: NO

Type of perforator used

Size of perforations in by in.

perforations from ft to ft

perforations from ft to ft

perforations from ft to ft

Screens: YES

Manufacturer's Name HOWARD SMITH

Type STAINLESS STEEL Model No

Diam 6 Slot size 15 from 235 ft. to 240 ft.

Diam Slot size from ft to ft.

Gravel packed: NO Size of gravel

Gravel placed from ft to ft

Surface seal: YES To what depth? 18 ft.

Material used in seal BENTONITE

Did any strata contain unusable water? NO

Type of water? Depth of strata ft.

Method of sealing strata off

(7) PUMP: Manufacturer's Name

Type

(8) WATER LEVELS: Land-surface elevation above mean sea level ft.

Static level 213.6 ft. below top of well Date 08/31/94

Artesian Pressure lbs. per square inch Date

Artesian water controlled?

(9) WELL TESTS: Drawdown is amount water level is lowered below static level.

Was a pump test made? NO If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

Recovery data

| Time | Water Level | Time | Water Level | Time | Water Level |
|---|---|---|---|---|---|

Date of test / /

Bailer test 10 gal./min. .5 ft. drawdown after 1 hrs.

Air test cu. ft./min. with item set at ft. for hrs.

Artesian flow G.P.M. Date

Temperature of water Was a chemical analysis made? NO

Formations (describe by color, character, size of materials and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change in formation)

| MATERIAL | FROM | TO |
|---|---|---|
| TOPSOIL | 0 | 1 |
| BROWN GRAVEL WOOD & CLAY | 1 | 5 |
| BROWN SILT SAND GRAVEL | 5 | 58 |
| & CLAY | 5 | 58 |
| BROWN SAND CLAY & GRAVEL | 58 | 62 |
| BROWN SAND & GRAVEL | 62 | 90 |
| GRAY SAND & GRAVEL | 90 | 100 |
| GRAY SAND & CLAY | 100 | 105 |
| GRAY SILT SAND & GRAVEL | 105 | 115 |
| GRAY SILT & CLAY | 115 | 117 |
| GRAY CLAY | 117 | 154 |
| GRAY SILT & SAND | 154 | 160 |
| GRAY SAND & CLAY | 160 | 170 |
| GRAY SILT & SAND | 170 | 176 |
| GRAY CLAY | 176 | 180 |
| GRAY SILT SAND & CLAY | 180 | 200 |
| GRAY SAND & CLAY | 200 | 212 |
| GRAY SAND | 212 | 220 |
| GRAY SAND GRAVEL & WATER | 220 | 242 |
| BROWN CLAY | 242 | |

RECEIVED
OCT 05 1994
DEPT. OF ECOLOGY

Work started 08/30/94 Completed 08/31/94

WELL CONSTRUCTOR CERTIFICATION:
I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME HAYES DRILLING, INC.
(Person, firm, or corporation) (Type or print)

ADDRESS 556 ERSHIG RD. BOW, WA

[SIGNED] Ryan Williams License No. 2190

Contractor's Registration No. HAYESDI106J5 Date 10 02 94

WELL SITE MEETS ALL SIGHTING CRITERIA UNDER I.C.C. 8.09 BASED ON INFORMATION SUPPLIED BY THE OWNER OR OWNER'S AUTHORIZED REPRESENTATIVE.

3701