29/03/05G) G1-24604

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Application No. .....

Permit No. .....

(1) OWNER: Name L.A. COLLENDER Address 5000 SOUTH BAY VIEW ROAD, LANGLEY 98260

(2) LOCATION OF WELL: County ISLAND — SW ¼ NE ¼ Sec. 5 T. 29 N., R. 3 E. W.M.

Bearing and distance from section or subdivision corner 820 NORTH / 750 EAST FROM CENTER SEC 5

(3) PROPOSED USE: Domestic ☐ Industrial ☐ Municipal ☐ Irrigation ☐ Test Well ☒ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) #2 (B)

New well ☒ Deepened ☐ Reconditioned ☐

Method: Dug ☐ Bored ☐ Cable ☒ Driven ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.

Drilled 157 ft. Depth of completed well 155 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6" Diam. from 0 ft. to 150 ft.

Threaded ☐ " Diam. from ft. to ft.

Welded ☒ " Diam. from ft. to ft.

Perforations: Yes ☐ No ☒

Type of perforator used

SIZE of perforations in. by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

Screens: Yes ☒ No ☐

Manufacturer's Name SMITH

Type Model No.

Diam. 6 Slot size 10 from 150 ft. to 155 ft.

Diam. Slot size from ft. to ft.

Gravel packed: Yes ☐ No ☒ Size of gravel:

Gravel placed from ft. to ft.

Surface seal: Yes ☒ No ☐ To what depth? 18 ft.

Material used in seal BENTONITE

Did any strata contain unusable water? Yes ☐ No ☒

Type of water? Depth of strata

Method of sealing strata off

(7) PUMP: Manufacturer's Name STA RITE

Type: SUB H.P. 1

(8) WATER LEVELS: Land-surface elevation above mean sea level 160 ft.

Static level 136 ft. below top of well Date 11-15-76

Artesian pressure lbs. per square inch Date

Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes ☒ No ☐ If yes, by whom? DRILLER

Yield: 15 gal./min. with 10 ft. drawdown after 24 hrs.

" " " "

" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? Yes ☐ No ☒

(10) WELL LOG:

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
TOP SOIL	0	1
BROWN MED SAND	1	45
" CLAY & SAND	45	130
" FINE SAND WW	130	145
GRAY MED SAND WW	145	155
BROWN SILT	155	156

Work started 10-1, 19 76 Completed 10-15, 19 76

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME B & W DRILLING CO (Person, firm, or corporation) (Type or print)

Address P.O. BOX 55 FREELAND WA 98249

[Signed] [signature] (Well Driller)

License No. 265 Date 11-24, 19 76

(USE ADDITIONAL SHEETS IF NECESSARY)

S. F. No. 7356—OS—(Rev. 4-71).