File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

ENTERED

WATER WELL REPORT
STATE OF WASHINGTON

Start Card No. W-054105
UNIQUE WELL I.D. #
Water Right Permit No. 29/3E/4-C

(1) OWNER: Name Pinewood Community Club Address P.O Box 224 Langley WA. 98260

(2) LOCATION OF WELL: County ISLAND NE 1/4 NW 1/4 Sec. 4 T. 29 N., R. 3E W.M.

(2a) STREET ADDRESS OF WELL (or nearest address) 4911 Pinewood Rd Langley 98260

(3) PROPOSED USE: [X] Domestic [ ] Irrigation [ ] DeWater [ ] Industrial [ ] Test Well [ ] Municipal [ ] Other

(4) TYPE OF WORK: Owner's number of well (if more than one) 2
Abandoned [ ] New well [X] Deepened [ ] Reconditioned [ ]
Method: Dug [ ] Cable [X] Rotary [ ] Bored [ ] Driven [ ] Jetted [ ]

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 103 feet. Depth of completed well 103 ft.

(6) CONSTRUCTION DETAILS:
Casing installed: 6" Diam. from 0 ft. to 88 ft.
Welded [X] " Diam. from ft. to ft.
Liner installed [ ] " Diam. from ft. to ft.
Threaded [ ]

Perforations: Yes [ ] No [X]
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes [X] No [ ]
Manufacturer's Name COOK
Type STAINLESS Model No.
Diam. 6 Slot size 12 from 88 ft. to 98 ft.
Diam. 6 Slot size 10 from 98 ft. to 103 ft.

Gravel packed: Yes [ ] No [X] Size of gravel
Gravel placed from ft. to ft.

Surface seal: Yes [X] No [ ] To what depth? 18+ ft.
Material used in seal BENTONITE
Did any strata contain unusable water? Yes [ ] No [X]
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name H.P.
Type:

(8) WATER LEVELS: Land-surface elevation above mean sea level 140 ft.
Static level 68' ft. below top of well Date 7-95
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes [X] No [ ] If yes, by whom? Bob Pump
Yield: 20 gal./min. with ft. drawdown after hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test
Bailer test 20 gal./min. with 6 ft. drawdown after 4 hrs.
Airtest gal./min. with stem set at ft. for hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes [X] No [ ]

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
Dirty Sand	0	4
Sandy Hard Pan	4	35
Dirty Sand (compact)	35	68
Water Sand	68	104
Sand Finer	104	

RECEIVED
JUL 18 1995
DEPT. OF ECOLOGY

Work Started 7, 1995 Completed 7-10, 1995

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME Whidbey Drillers (PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)
Address Oak Harbor WA.
(Signed) Dennis Jones (WELL DRILLER) License No. 129
Contractor's Registration No. WHIDBWD 289 mm Date July 10, 1995

(USE ADDITIONAL SHEETS IF NECESSARY)

Ecology is an Equal Opportunity and Affirmative Action employer. For special accommodation needs, contact the Water Resources Program at (206) 407-6600. The TDD number is (206) 407-6006.

ECY 050-1-20 (9/93)