ENTERED

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Start Card No. W063677
UNIQUE WELL I.D. # Please Send
Water Right Permit No. 30-2-19 R

(1) OWNER: Name Frank H. EATON Address 3860 S. Smuggler Cove Rd - Clinton

(2) LOCATION OF WELL: County Island SE 1/4 SE 1/4 Sec. 19 T. 30 N., R. 2 W.M.

(2a) STREET ADDRESS OF WELL (or nearest address) Parcel # R23019-204-2380

(3) PROPOSED USE: ☐ Domestic ☐ Irrigation ☐ DeWater Industrial ☐ Test Well ☐ Municipal ☑ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one)
Abandoned ☐ New well ☑ Deepened ☐ Reconditioned ☐
Method: Dug ☐ Cable ☑ Rotary ☐ Bored ☐ Driven ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 166 feet. Depth of completed well 166 ft.

(6) CONSTRUCTION DETAILS:
Casing installed: 6 " Diam. from +2 ft. to 161 ft.
Welded ☑ " Diam. from ft. to ft.
Liner installed ☐
Threaded ☐ " Diam. from ft. to ft.

Perforations: Yes ☐ No ☑
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes ☑ No ☐
Manufacturer's Name WESCO
Type SS Model No.
Diam. 5 Slot size 14 from 161 ft. to 166 ft.
Diam. Slot size from ft. to ft.

Gravel packed: Yes ☐ No ☑ Size of gravel
Gravel placed from ft. to ft.

Surface seal: Yes ☑ No ☐ To what depth? 18 ft.
Material used in seal Bentonite
Did any strata contain unusable water? Yes ☐ No ☑
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name Myers
Type: Ranger 330125B H.P. 3

(8) WATER LEVELS: Land-surface elevation above mean sea level 200 ft.
Static level 109 ft. below top of well Date 2/4/97
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☑ No ☐ If yes, by whom? Joe Lehman
Yield: 42 gal./min. with 26 ft. drawdown after 4½ hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level
0 min	135				
2½ min	109				

Date of test 2/4/97
Bailer test gal./min. with ft. drawdown after hrs.
Airtest gal./min. with stem set at ft. for hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes ☑ No ☐

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
TOP SOIL	0	1
HARD PACKED GRAVEL & R	1	55
SILTY W GRAY	55	57
SAND MED GRAY	57	102
LAYER WATER SAND & R	102	160
COURSE SAND W W GR	160	166
CLAY GRAY	166	162

RECEIVED FEB 06 1997 DEPT. OF ECOLOGY

Work Started 1/20, 1997 Completed 2/4, 1997

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME Bobs Well Drilling (PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)
Address 6104 S. Maxwelton Rd-Clint
(Signed) (WELL DRILLER) License No. 0264
Contractor's Registration No. BOBSSB5101JW Date 2/5, 1997

(USE ADDITIONAL SHEETS IF NECESSARY)

Ecology is an Equal Opportunity and Affirmative Action employer. For special accommodation needs, contact the Water Resources Program at (206) 407-6600. The TDD number is (206) 407-6006.

ECY 050-1-20 (9/93) * * 1