File Original and First Copy with Department of Ecology
Second Copy—Owner's Copy
Third Copy—Driller's Copy

# WATER WELL REPORT

STATE OF WASHINGTON

Start Card No. 2004671
30/3/4Q
Water Right Permit No.

(1) OWNER: Name Ron Coster, Craig Carliss, Charles Russell Address P.O. Box 561 Duvall, Wash. 98019

(2) LOCATION OF WELL: County Island SW ¼ SE ¼ Sec. 4 T. 30 N., R. 3 E W.M.

(2a) STREET ADDDRESS OF WELL (or nearest address) 2676 S. Broadmoor Rd. Camano Is. Wash

(3) PROPOSED USE: [X] Domestic [ ] Irrigation [ ] DeWater Industrial [ ] Test Well [ ] Municipal [ ] Other [ ]

(4) TYPE OF WORK: Owner's number of well (if more than one)
Abandoned [ ] New well [X] Deepened [ ] Reconditioned [ ]
Method: Dug [ ] Cable [X] Rotary [ ] Bored [ ] Driven [ ] Jetted [ ]

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 255 feet. Depth of completed well 255 ft.

(6) CONSTRUCTION DETAILS:
Casing installed: 6 " Diam. from +1 ft. to 251 ft.
Welded [X] " Diam. from ft. to ft.
Liner installed [ ] Threaded [ ] " Diam. from ft. to ft.

Perforations: Yes [ ] No [X]
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes [X] No [ ]
Manufacturer's Name Johnson
Type Stainless Model No.
Diam. 5 Slot size 6 from 250 ft. to 255 ft.
Diam. Slot size from ft. to ft.

Gravel packed: Yes [ ] No [X] Size of gravel
Gravel placed from ft. to ft.

Surface seal: Yes [X] No [ ] To what depth? 18 ft.
Material used in seal Bentonite
Did any strata contain unusable water? Yes [ ] No [X]
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name N/A
Type: H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level 200 ft.
Static level 195 ft. below top of well Date 6/10/92
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.))

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes [ ] No [X] If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

| Time | Water Level | Time | Water Level | Time | Water Level |
|---|---|---|---|---|---|
| | | | | | |

Date of test
Bailer test 20 gal./min. with 5 ft. drawdown after 2 hrs.
Airtest gal./min. with stem set at ft. for hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes [ ] No [X]

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

| MATERIAL | FROM | TO |
|---|---|---|
| Sand | 0 | 192 |
| brown clay | 192 | 196 |
| blue clay | 196 | 208 |
| brown clay | 208 | 218 |
| Silt | 218 | 226 |
| blue clay | 226 | 233 |
| Silt | 233 | 250 |
| Fine sand | 250 | 255 |

Work started 6/4/92, 19. Completed 6/10/92, 19

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME Kounkel Well Drilling (PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)
Address 097 N. Smith Rd. Camano Is. Wa.
(Signed) Larry Kounkel (WELL DRILLER) License No. 1892
Contractor's Registration No. KOUNKWD099KT Date 6/11, 1992

(USE ADDITIONAL SHEETS IF NECESSARY)

ECY 050-1 20 (10/87) 1329 3