30/03/05D

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT
STATE OF WASHINGTON

Application No.

Permit No. ...

(1) OWNER: Name Jon Stoneman Address 2506 W. Lk Sammish Rd. S.E. Bellevue

(2) LOCATION OF WELL: County Island — NW¼ NW¼ Sec. 5 T. 30 N., R. 3 W.M.

Bearing and distance from section or subdivision corner

(3) PROPOSED USE: Domestic ☒ Industrial ☐ Municipal ☐ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) 2

New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☒ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 165 ft. Depth of completed well 165 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6 " Diam. from +15" ft. to 144½ ft.
Threaded ☐ " Diam. from ft. to ft.
Welded ☐ " Diam. from ft. to ft.

Perforations: Yes ☐ No ☒
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes ☒ No ☐
Manufacturer's Name Johnson
Type Stainless Model No.
Diam. 5 Slot size 18 from 144 ft. to 149 ft.
Diam. Slot size from ft. to ft.

Gravel packed: Yes ☐ No ☒ Size of gravel:
Gravel placed from ft. to ft.

Surface seal: Yes ☒ No ☐ To what depth? 18 ft.
Material used in seal Bentonite
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name
Type: H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level ft.
Static level 143.6" ft. below top of well Date 4/3/86
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☒ No ☐ If yes, by whom?
Yield: gal./min. with 4 ft. drawdown after 4 hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test
Bailer test gal./min. with ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes ☒ No ☐

(10) WELL LOG:

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Sand	0	84
Clayey Sand	84	110
Brown Clay	110	113
Clayey Sand	113	144
Coarse Sand	144	165

RECEIVED
JUN 13 1986
DEPARTMENT OF ECOLOGY
NORTHWEST REGION

Work started 3/27, 1986. Completed , 19

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Kounkel Well Drilling (Person, firm, or corporation) (Type or print)

Address 797 N. Smith Rd. Ge

[Signed] Larry Kounkel (Well Driller)

License No. 1174 Date 4/8, 1986

(USE ADDITIONAL SHEETS IF NECESSARY)

ECY 050-1-20