File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

B+W DRILLING Co.

WATER WELL REPORT

STATE OF WASHINGTON

#2 | 31/2-33 P

Application No.

Permit No. G1-24218

(1) OWNER: Name Beach Acumber Water Assoc. Address P.O. Box 37 Greenbank Wash.

(2) LOCATION OF WELL: County Island — NW ¼ SW ¼ Sec. 33 T. 31 N., R. 2E W.M.

Bearing and distance from section or subdivision corner (1100' W & 1000' N - S 1/4 COR. - SEC. 33)

(3) PROPOSED USE: Domestic ☑ Industrial ☐ Municipal ☑ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) #2

New well ☐ Deepened ☑ Reconditioned ☐

Method: Dug ☐ Bored ☐ Cable ☐ Driven ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.

Drilled 445 ft. Depth of completed well 440 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6" Diam. from 0 ft. to 420 ft.

Threaded ☐ " Diam. from ft. to ft.

Welded ☑ " Diam. from ft. to ft.

Perforations: Yes ☐ No ☑

Type of perforator used

SIZE of perforations in. by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

Screens: Yes ☑ No ☐

Manufacturer's Name COOK

Type Stainless Steel welded Model No.

Diam 6 Slot size 14 from 420 ft. to 440 ft.

Diam Slot size from ft. to ft.

Gravel packed: Yes ☐ No ☑ Size of gravel:

Gravel placed from ft. to ft.

Surface seal: Yes ☑ No ☐ To what depth? 30' ft.

Material used in seal 8" Casing

Did any strata contain unusable water? Yes ☐ No ☑

Type of water? Depth of strata

Method of sealing strata off

(7) PUMP: Manufacturer's Name

Type H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level 300 ft.

Static level 263' ft. below top of well Date 9/20/83

Artesian pressure lbs. per square inch Date

Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes ☐ No ☑ If yes, by whom?

Yield gal./min. with ft. drawdown after hrs.

" " " "

" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test

Bailer test 50 gal./min. with 40 ft. drawdown after 2½ hrs.

Artesian flow g.p.m. Date 8/12/83

Temperature of water Was a chemical analysis made? Yes ☐ No ☐

(10) WELL LOG:

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Sand & Clay Gr	0	6
Clay with Rocks Gr	6	70
Hard Pan with Rocks Gr	70	240
Sand & Gravel Gr	240	288
Hard Pan Gr	288	310
Hard Pan w/w Gray	310	385
Sand Coarse w/w Gray	385	440

Work started 8/14, 19 83 Completed 8/16, 19 83

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME B+W Well Drilling (Person, firm, or corporation) (Type or print)

Address P.O. Box 55, Freeland, Wa 98249

[Signed] (Well Driller)

License No. 264 Date 8/19, 19 83

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

B+W DRILLING Co.

WATER WELL REPORT

STATE OF WASHINGTON

Application No. #2

Permit No.

(1) OWNER: Name Beachcomber Water Assoc. Address P.O. Box 34 GREENBANK Wash

(2) LOCATION OF WELL: County Island — NW ¼ SW ¼ Sec. 33 T. 31 N., R. 2E W.M.

Bearing and distance from section or subdivision corner

(3) PROPOSED USE: Domestic ☐ Industrial ☐ Municipal ☑ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) #2

New well ☑ Deepened ☐ Reconditioned ☐

Method: Dug ☐ Bored ☐ Cable ☐ Driven ☐ Rotary ☑ Jetted ☐

(5) DIMENSIONS: Diameter of well 8" inches.

Drilled 380 ft. Depth of completed well ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 8" Diam. from 0 ft. to 300' ft.

Threaded ☐ " Diam. from ft. to ft.

Welded ☑ " Diam. from ft. to ft.

Perforations: Yes ☐ No ☑

Type of perforator used

SIZE of perforations in. by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

Screens: Yes ☐ No ☑

Manufacturer's Name

Type Model No.

Diam. Slot size from ft. to ft.

Diam. Slot size from ft. to ft.

Gravel packed: Yes ☐ No ☑ Size of gravel:

Gravel placed from ft. to ft.

Surface seal: Yes ☐ No ☐ To what depth? ft.

Material used in seal

Did any strata contain unusable water? Yes ☐ No ☐

Type of water? Depth of strata

Method of sealing strata off

(7) PUMP: Manufacturer's Name

Type: H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level 300' ft.

Static level ft. below top of well Date

Artesian pressure lbs. per square inch Date

Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes ☐ No ☐ If yes, by whom?

Yield: gal./min with ft. drawdown after hrs.

" " " "

" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test

Bailer test gal./min with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? Yes ☐ No ☐

(10) WELL LOG:

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Sand & Clay Gray	0	6
Clay with Rock Gr	6	70
HARD Pan with Rock Gr	70	240
Sand & Gravel Gr.	240	288
Hard Pan Gr.	288	310
Hard Pan S.W. Gr.	310	385
STOPPED DRILLING		

Work started 10/4, 19 82 Completed 10/30, 19 82

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME B+W Well Drilling (Person, firm, or corporation) (Type or print)

Address P.O. Box 55, Freeland, Wa 98249

[Signed] Joe Lehman (Well Driller)

License No. 264 Date 10/22, 19 84

Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT
STATE OF WASHINGTON

✓ 31/2-32 (E)

Permit No. ....

(1) OWNER: Name BEACH COLBER Address PO Box 47 GREENBANK

(2) LOCATION OF WELL: County ISLAND — SW¼ NW¼ Sec. 32 T. 31 N., R. 2 W.M.

Bearing and distance from section or subdivision corner 2300 FT W Cent Sec 32 500 FT S

(3) PROPOSED USE: Domestic ☐ Industrial ☐ Municipal ☒ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) ....
New well ☐ Method: Dug ☐ Bored ☐
Deepened ☒ Cable ☐ Driven ☐
Reconditioned ☐ Rotary ☒ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 445 ft. Depth of completed well 440 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6" Diam. from 0 ft. to 420 ft.
Threaded ☐ ....." Diam. from ..... ft. to ..... ft.
Welded ☒ ....." Diam. from ..... ft. to ..... ft.

Perforations: Yes ☐ No ☐
Type of perforator used .....
SIZE of perforations ..... in. by ..... in.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.

Screens: Yes ☒ No ☐
Manufacturer's Name COOK
Type SS WELD Model No. .....
Diam. 6 Slot size 14 from 420 ft. to 440 ft.
Diam. ..... Slot size ..... from ..... ft. to ..... ft.

Gravel packed: Yes ☐ No ☐ Size of gravel: .....
Gravel placed from ..... ft. to ..... ft.

Surface seal: Yes ☒ No ☐ To what depth? ..... ft.
Material used in seal .....
Did any strata contain unusable water? Yes ☐ No ☐
Type of water? ..... Depth of strata .....
Method of sealing strata off .....

(7) PUMP: Manufacturer's Name .....
Type: ..... H.P. .....

(8) WATER LEVELS: Land-surface elevation above mean sea level .... 280 ft.
Static level 320 ft. below top of well Date .....
Artesian pressure ..... lbs. per square inch Date .....
Artesian water is controlled by ..... (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☐ No ☐ If yes, by whom? .....
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test .....
Bailer test 50 gal./min. with 40 ft. drawdown after 2½ hrs.
Artesian flow ..... g.p.m. Date 8/17/83
Temperature of water ..... Was a chemical analysis made? Yes ☐ No ☐

(10) WELL LOG:

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
SAND + CLAY GR	0	6
CLAY W ROCKS GR	6	70
HARD PAN W ROCKS GR	70	240
SAND + GRAVEL GR	240	288
HARD PAN GR	288	310
HARD PAN WW GRAY	310	385
SAND COARSE WW GRAY	385	440

RECEIVED
APR 29 1987
DEPARTMENT OF ECOLOGY
NORTHWEST REGION

WELD OFF 6" CASING TO 5" CASING + GROUTED DOWN 8' FROM TOP

RECEIVED
MAY 4 1987
ISLAND COUNTY
HEALTH DEPARTMENT

Work started 8/14/83, 19..... Completed 8/16/83 19.....

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME B+W DRILLING (Person, firm, or corporation) (Type or print)

Address 1087 E DRILK RD

[Signed] J. HLL (Well Driller)

License No. 244 Date 8/18, 1983

(USE ADDITIONAL SHEETS IF NECESSARY)

ECY 050-1-20

WASHINGTON STATE DEPARTMENT OF ECOLOGY

Well Tagging Form

Unique Well Tag No: AGA415 S02

RECORD VERIFICATION (check ✓ one)

- [ ] Well Report available *(please attach this form to the well report and submit it to the Ecology Regional Office near you)*
- [ ] Verification inconclusive
- [ ] Well Report not available

WELL OWNERSHIP, IF DIFFERENT FROM WELL REPORT

First Name BEACHCOMBER W SUPP. Last Name _____

Street Address 04979-V

City _____ State _____

LOCATION OF WELL, IF DIFFERENT FROM WELL REPORT

Well Address CUTHBERT / MASTADON

City _____ County _____

T _____ N R _____ _____ W M Sec _____ _____ 1/4 of the _____

FOR AGENCY USE ONLY

Latitude _____ _____ _____ _____

Longitude _____ _____ _____ _____

- [ ] GPS
- [ ] Topographic Map
- [ ] Survey
- [ ] Computer generated

Elevation at land surface _____ feet/meters *(circle one)*

- [ ] Digital Altimeter
- [ ] Topographic Map
- [ ] Other _____

Additional information, if available

- [ ] Location marked on topographic map *(please attach)*
- [ ] Location marked on air photo *(please attach)*

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

FOR AGENCY USE ONLY

WELL CHARACTERISTICS

ysical Description of well (size of casing type of well, housing etc)

6" CASING - HEAD EXPOSED BETWEEN RES's SRL #2 NEAR

TAN PH ALL INSIDE CHAIN LINK FENCE

cation of Well Identification Tag

CASING

as supplemental tag needed for ease of identifying well? ☐ Yes ☒ No

es where was tag placed? _____

D	C	B	A
E	F	G	H
M	L	K	J
N	P	Q	R

Scale 1 24 000 (1 =2 000)

Indicate the location of the well within the Section by drawing a dot at that point

SECTION _____

MMENTS

FOR ECOLOGY WATER RESOURCES PROGRAM ONLY

r Right # _____ Date Issued _____

e One Application Permit Certificate Claim Exempt