File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Application No. 31/03-31H

Permit No.

(1) OWNER: Name Donald K. Moa Address 27704-85th Dr. NW Stanwood 98292

(2) LOCATION OF WELL: County Island 3-½ SE¼ NE¼ Sec 31 T. 31 N., R. 3 W.M.

Bearing and distance from section or subdivision corner

(3) PROPOSED USE: Domestic ☐ Industrial ☐ Municipal ☑ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one)

New well ☑ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☑ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 290 ft. Depth of completed well 290 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6" Diam. from 0 ft. to 279 ft.
Threaded ☐ " Diam. from ft. to ft.
Welded ☑ " Diam. from ft. to ft.

Perforations: Yes ☐ No ☑
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes ☑ No ☐
Manufacturer's Name Johnson
Type Wire Model No. 3021
Diam. 6 Slot size 20 from 279 ft. to 290 ft.
Diam. Slot size from ft. to ft.

Gravel packed: Yes ☐ No ☑ Size of gravel:
Gravel placed from ft. to ft.

Surface seal: Yes ☑ No ☐ To what depth? 20 ft.
Material used in seal bentonite & clay
Did any strata contain unusable water? Yes ☐ No ☑
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name
Type: H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level 206 ft.
Static level 206 ft. below top of well Date 7/20/81
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☑ No ☐ If yes, by whom? Driller
Yield: 20 gal./min. with 4 ft. drawdown after 4 hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level
0.00	210				
0.02	206				

Date of test 7/20/81
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 52 Was a chemical analysis made? Yes ☑ No ☐

(10) WELL LOG:

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Sand	0	176
gravel	176	208
blue clay	208	272
med sand	272	290

Work started 7/8, 1981 Completed 7/20, 1981

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Kaunhel Well Drilling (Person, firm, or corporation) (Type or print)

Address 797 N Smith Rd Camano Is Wa 98282

[Signed] A. G. Kaunhel (Well Driller)

License No. 0247 Date 7/24, 1981

(USE ADDITIONAL SHEETS IF NECESSARY)

ECY 050-1-20