32/01-8M

Copy with
Owner's Copy
Driller's Copy

WATER WELL REPORT
STATE OF WASHINGTON

Application No. .....
Permit No. G1-24219

(1) OWNER: Name E. BRIDGE A. DELKWA Address 1307 W. SCANTOTON, OAK HARBOR WN

(2) LOCATION OF WELL: County ISLAND ¼ ¼ Sec. 3 T. 32 N., R. 1 W.M.
Bearing and distance from section or subdivision corner (100' S & 830' E FROM W 1/4 COR-SEC. 8)

(3) PROPOSED USE: Domestic ☐ Industrial ☐ Municipal ☒ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) 1
New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☒ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 265 ft. Depth of completed well 265 ft.

(6) CONSTRUCTION DETAILS:
Casing installed: 6" Diam. from 0 ft. to 255 ft.
Threaded ☐ ....." Diam. from ..... ft. to ..... ft.
Welded ☒ ....." Diam. from ..... ft. to ..... ft.

Perforations: Yes ☐ No ☒
Type of perforator used .....
SIZE of perforations ..... in. by ..... in.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.

Screens: Yes ☒ No ☐
Manufacturer's Name Johnson
Type STAINLESS Model No. .....
Diam. 6 Slot size 10 from 255 ft. to 265 ft.
Diam. ..... Slot size ..... from ..... ft. to ..... ft.

Gravel packed: Yes ☐ No ☒ Size of gravel: .....
Gravel placed from ..... ft. to ..... ft.

Surface seal: Yes ☒ No ☐ To what depth? 18+ ft.
Material used in seal BENTONITE
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? ..... Depth of strata .....
Method of sealing strata off .....

(7) PUMP: Manufacturer's Name .....
Type: ..... H.P. .....

(8) WATER LEVELS: Land-surface elevation above mean sea level (230) ft.
Static level 222 ft. below top of well Date MAY 79
Artesian pressure ..... lbs. per square inch Date .....
Artesian water is controlled by ..... (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☐ No ☐ If yes, by whom? .....
Yield: ..... gal./min. with ..... ft. drawdown after ..... hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test .....
Bailer test 20 gal./min. with ..... ft. drawdown after 6 hrs.
Artesian flow ..... g.p.m. Date .....
Temperature of water ..... Was a chemical analysis made? Yes ☐ No ☐

(10) WELL LOG:

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
SAND	0	14
TIGHT HARD SAND	14	106
SANDY CLAY	106	145
TRACE OF H2O	145	147
SANDY CLAY	147	184
SANDY	184	204
SANDY CLAY	204	244
FINE SCUPY SAND	244	253
WATER SAND #10	253	265

RECEIVED
OCT 15 1984
DEPARTMENT OF ECOLOGY
NORTHWEST REGION

PUMP TEST - 8-2-79
BOBS PUMPS
30 GPM, FROM SWL 224.5'
DD TO 241.17' 15 MIN, TEST
STABLE TILL END 4 HR TEST
FULL RECOVERY 1 MIN

Work started APRIL 1979 Completed MAY 1979

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Whidbey Drillers (Person, firm, or corporation) (Type or print)

Address OAK HARBOR, WN 98277

[Signed] Dennis Faber (Well Driller)

License No. 129 Date MAY, 1979