B+W DRILLING Co.

32/01/05M

Application No

WATER WELL REPORT

STATE OF WASHINGTON

Permit No

Christie

(1) OWNER: Name Ellison Realty Address West Beach

(2) LOCATION OF WELL: County Island — ¼ ¼ Sec. T. N., R. W.M.

Bearing and distance from section or subdivision corner Code M NW SW 5 32 1E

(3) PROPOSED USE: Domestic ☒ Industrial ☐ Municipal ☐ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one)

New well ☐ Deepened ☐ Reconditioned ☐

Method: Dug ☐ Bored ☐ Cable ☒ Driven ☐ Rotary ☐ Jetted ☐

5) DIMENSIONS; Diameter of well 6 inches.

Drilled 334 ft. Depth of completed well 334 ft.

6) CONSTRUCTION DETAILS:

Casing installed: 6 " Diam. from 0 ft. to 324' ft.

Threaded ☐ " Diam. from ft. to ft.

Welded ☒ " Diam. from ft. to ft.

Perforations: Yes ☐ No ☒

Type of perforator used

SIZE of perforations in. by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

Screens: Yes ☒ No ☐

Manufacturer's Name Johnson

Type Stainless Steel Model No.

Diam Slot size 10 from 324 ft. to 329 ft.

Diam Slot size 10 from 329 ft. to 334 ft.

Gravel packed: Yes ☐ No ☒ Size of gravel:

Gravel placed from ft. to ft.

Surface seal: Yes ☐ No ☒ To what depth? ft.

Material used in seal

Did any strata contain unusable water? Yes ☐ No ☐

Type of water? Depth of strata

Method of sealing strata off

(7) PUMP: Manufacturer's Name

Type: Submersible H.P. 3

(8) WATER LEVELS: Land-surface elevation above mean sea level — ft.

Static level 247' ft. below top of well Date 1-74

Artesian pressure lbs per square inch Date

Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes ☒ No ☐ If yes, by whom? Driller

Yield: 30 gal./min with 27' ft. drawdown after 4 hrs

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test

Bailer test gal./min with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? Yes ☐ No ☒

(10) WELL LOG:

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	3
HARD PAN	3	10
Sand Med. Brown hard packed	10	35
Sand Coarse " "	35	50
SAND Fine " "	50	95
ROCK	95	98
SAND Fine Gray	98	165
Clay + Sand Brown	165	252
SAND Clean W.W.	252	255
Black Peat	255	261
Clay + Sand Fine	261	300
Clay + Sand Coarse	300	320
SAND Course W.W.	320	334
CLAY	334	-

RECEIVED
DEC 19 1985
DEPARTMENT OF ECOLOGY
NORTHWEST REGION

Work started 19 Completed JAN 1974

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME B+W Well Drilling (Person, firm, or corporation) (Type or print)

Address P.O. Box 55, Freeland, W 98249

[Signed] WALLY LEHMAN (Well Driller)

License No. 0265 Date JAN. 1974

22# Pressure @ elev. 132 ; 120 G.P.M. @ elev 26

N. ter 2.	Time H + M	Lapsed Time	Draw Down Gauge	Draw Down Drop	RECOVERY Time	RECOVERY Gauge
	3:30	0	58	Static		
	35	5 Min	57	1		
	40	10 "	55	3		
	45	15 "	52	6		
	50	20 "	52	6		
	55	25 "	52	6		
	4:00	½ Hour	52	6		
	4:30	1 Hour	52	6		
	5:00	1½ "	52½	5½		
4	5:30	2 "	52½	5½		
	6:00	2½	53	5		
	6:01		55	3	Recovery	
overq	6:03		59	+1		
	6:05		60	+2		
	6:10		60	+2		

tal Gals (2.5)(60)(120) = 18,000 Gals

RECEIVED
DEC 19 1985
DEPARTMENT OF ECOLOGY
NORTHWEST REGION

21/8 Whidbey West Well #3 @ Sandy Bubbles. Bg $