7937

WATER WELL REPORT
STATE OF WASHINGTON

Start Card No. W118447
Water Right Permit No. AFA 676

(1) OWNER: Name HOOK, BYRON Address 900 ELLIOT AVE W SEATTLE, WA 98119-

(2) LOCATION OF WELL: County ISLAND - SE 1/4 SE 1/4 Sec 10 T 29 N., R 3E WM
(2a) STREET ADDRESS OF WELL (or nearest address) 5586 LANGLEY RD

(3) PROPOSED USE: DOMESTIC

(4) TYPE OF WORK: Owner's Number of well (If more than one) 1
NEW WELL Method: ROTARY

(5) DIMENSIONS: Diameter of well 6 inches
Drilled 178.5 ft. Depth of completed well 178.5 ft.

(6) CONSTRUCTION DETAILS:
Casing installed: 6 Dia. from +2 ft. to 174.5 ft.
WELDED Dia. from ft. to ft.
Dia. from ft. to ft.

Perforations: NO
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: YES
Manufacturer's Name COOK
Type STAINLESS STEEL Model No.
Diam. 6 slot size 12 from 173.5 ft. to 178.5 ft.
Diam. slot size from ft. to ft.

Gravel packed: NO Size of gravel
Gravel placed from ft. to ft.

Surface seal: YES To what depth? 18 ft.
Material used in seal BENTONITE
Did any strata contain unusable water? NO
Type of water? Depth of strata ft.
Method of sealing strata off

(7) PUMP: Manufacturer's Name FLINT & WALLING
Type SUBMERSIBLE H.P. 1.0

(8) WATER LEVELS: Land-surface elevation above mean sea level ... ft.
Static level 144.4 ft. below top of well Date 12/06/99
Artesian Pressure lbs. per square inch Date
Artesian water controlled by

(10) WELL LOG 29-3E-10R

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change in formation.

MATERIAL	FROM	TO
TOPSOIL	0	1
BROWN SAND & GRAVEL	1	6
BROWN SILT SAND & GRAVEL	6	14
BROWN SILT & SAND	14	18
BROWN SILT SAND & GRAVEL	18	21
BROWN SAND & GRAVEL	21	29
GRAY SILT SAND & GRAVEL	29	38
BROWN GRAVEL & SAND	38	43
BROWN SAND & GRAVEL	43	80
BROWN SAND SCATTERED GRAVL	80	153
BROWN SAND & WATER	153	

DEC 20 1999
DEPARTMENT OF ECOLOGY
EASTERN REGION

DEC 30 1999

Work started 12/03/99 Completed 12/06/99

(9) WELL TESTS: Drawdown is amount water level is lowered below static level.
Was a pump test made? YES If yes, by whom? HAYES DRILLING
Yield: 15 gal./min with 9.25 ft. drawdown after 2 hrs.

Recovery data
Time Water Level Time Water Level Time Water Level

Date of test
Bailer test 15 gal/min. 8 ft. drawdown after 1 hrs.
Air test gal/min. w/ stem set at ft. for hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? YES

WELL CONSTRUCTOR CERTIFICATION:
I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME HAYES DRILLING, INC.
(Person, firm, or corporation) (Type or print)

ADDRESS 5696 ERSHIG RD., BOW, WA

[SIGNED] Ryan Williams License No. 2190

Contractor's Registration No. HAYESDI106J5 Date 12/21/99

6917

Well site meets all sighting criteria under I.C.C. 8.09 based upon information supplied by the owner or owner's authorized representative.