32-1E-33K

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Start Card No. W100669
UNIQUE WELL I.D. # ABY 399
Water Right Permit No. [redacted] Replaces old #5

(1) OWNER: Name Town of Coupeville Address P.O. Box 725 - Coupeville

(2) LOCATION OF WELL: County Island NW 1/4 SE 1/4 Sec 33 T. 32 N. R. 1E W.M.

(2a) STREET ADDRESS OF WELL (or nearest address) Main St. - Coupeville - Well #5

(3) PROPOSED USE: ☑ Domestic ☐ Irrigation ☐ DeWater Industrial ☐ Test Well ☐ Municipal ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) ?
Abandoned ☐ New well ☑ Deepened ☐ Reconditioned ☐
Method: Dug ☐ Cable ☑ Rotary ☑ Bored ☐ Driven ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 8" inches.
Drilled 270 feet. Depth of completed well 270 ft.

(6) CONSTRUCTION DETAILS:
Casing installed: 8" Diam. from 0' ft. to 240' ft.
Welded ☑ Liner installed ☐ Threaded ☐
" Diam. from ft. to ft.
" Diam. from ft. to ft.

Perforations: Yes ☐ No ☑
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes ☑ No ☐
Manufacturer's Name Johson
Type SS Model No. 304
Diam. 8 Slot size 10,12,14 from 240 ft. to 255 ft.
Diam. 8 Slot size 15 from 256 ft. to 270 ft.

Gravel packed: Yes ☐ No ☑ Size of gravel
Gravel placed from ft. to ft.

Surface seal: Yes ☑ No ☐ To what depth? 18' ft.
Material used in seal Bentonite
Did any strata contain unusable water? Yes ☐ No ☑
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name Goulds
Type: Sub Turbine H.P. 30

(8) WATER LEVELS: Land-surface elevation above mean sea level Goulds ft.
Static level 103 ft. below top of well Date 5-1-00
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☑ No ☐ If yes, by whom? Driller
Yield: 300+ gal./min. with 98 ft. drawdown after 1+ hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test
Bailer test gal./min. with ft. drawdown after hrs.
Airtest gal./min. with stem set at ft. for hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes ☐ No ☐

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
Grey Clay	0	23
Grey Clay & Gravel	24	90
Brown SAND	91	96
Grey CLAY	97	212
Grey Water SAND	213	217
Grey SANDY CLAY	218	234
Grey Dirty Fine SAND	235	239
Fine Water SAND	240	255
Coarse SAND	256	270
Grey CLAY	271	—

RECEIVED
MAY 8 - 2000
NCWRO
DEPT OF ECOLOGY

Work Started 3/15 19. Completed 5-4 2000

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME WELL DONE DRILLERS (PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)
Address 440 Hill Valley Dr
(Signed) Jack E. Farris (WELL DRILLER) License No. 1304
Contractor's Registration No. WELL DON*025BV Date 5-4 19 00

(USE ADDITIONAL SHEETS IF NECESSARY)

Ecology is an Equal Opportunity and Affirmative Action employer. For special accommodation needs, contact the Water Resources Program at (206) 407-6600. The TDD number is (206) 407-6006.

ECY 050-1-20 (9/93) * * 1