93816

30-2E-36D

8866

WATER WELL REPORT
STATE OF WASHINGTON

Start Card No. W118176
AFN 206

(1) OWNER: Name SKYLINE WEST COMM. CLUB Address SKYLINE DRIVE FREELAND, WA

(2) LOCATION OF WELL: County ISLAND - NW 1/4 NW 1/4 Sec 36 T 30 N., R 2E WM

(2a) STREET ADDRESS OF WELL (or nearest address) 2177 NAUTILUS RD.

01 MAY -1 PM 2:56

(3) PROPOSED USE DOMESTIC

(4) TYPE OF WORK: Owner's Number of Well (If more than one)
NEW WELL Method ROTARY

DEPT OF ECOLOGY FISCAL & BUDGET

(5) DIMENSIONS. Diameter of well 6 inches
Drilled 380 ft. Depth of completed well 378 ft

(6) CONSTRUCTION DETAILS:
Casing installed 6 " Dia. from +2.3 ft. to 365 7 ft.
WELDED " Dia. from ft. to ft.
" Dia from ft. to ft.

Perforations: NO
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft to ft
perforations from ft. to ft.

Screens: YES
Manufacturer's Name COOK
Type STAINLESS STEEL Model No.
Diam. 6 slot size 18 from 361 ft. to 378 ft.
Diam. slot size from ft. to ft

Gravel packed NO Size of gravel
Gravel placed from ft. to ft

Surface seal: YES To what depth? 40 ft.
Material used in seal BENTONITE
Did any strata contain unusable water? NO
Type of water? Depth of strata ft
Method of sealing strata off

(7) PUMP: Manufacturer's Name FLINT & WALLING
Type SUBMERSIBLE H P 7 5

(8) WATER LEVELS: Land-surface elevation above mean sea level ... ft.
Static level 345 ft below top of well Date 04/25/01
Artesian Pressure lbs. per square inch Date
Artesian water controlled by

(10) WELL LOG

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change in formation.

MATERIAL	FROM	TO
TOPSOIL	0	1
BROWN SILT SAND & GRAVEL	1	10
GRAY SILT SAND & GRAVEL	10	78
GRAY SAND SCATTERED GRAVL	78	92
GRAY SILT SAND & GRAVEL CLAY	92	102
GRAY SAND & SILT SCATTERED GRAVL	102	160
GRAY SAND & SILT	160	200
GRAY SAND	200	270
GRAY CLAY	270	295
GRAY SAND	295	310
GRAY SAND & SILT	310	335
GRAY SAND	335	345
GRAY SAND & WATER	345	379
BROWN SAND WOOD & WATER	379	

Well site meets all sighting criteria under I.C.C. 8.09 based on information supplied by the owner or owner's authorized representative.

RECEIVED
MAY 0 3 2001
DEPARTMENT OF ECOLOGY
WELL DRILLING UNIT

Work started 04/16/01 Completed 04/23/01

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? YES If yes, by whom? HAYES DRILLING
Yield: 50+ gal./min with 3 ft drawdown after .25 hrs.

Recovery data

Time	Water Level	Time	Water Level	Time	Water Level

Date of test / /
Bailer test gal/min. ft drawdown after hrs.
Air test 15 gal/min. w/ stem set at 365 ft. for 1 5 hrs
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? NO

WELL CONSTRUCTOR CERTIFICATION:
I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME HAYES DRILLING, INC
(Person, firm, or corporation) (Type or print)

ADDRESS 5696 ERSKIG RD. BOW, WA

[SIGNED] License No 2189

Contractor's Registration No. HAYESDI106J5 Date 04/27/01

7246

93816