File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy 31/1E/11/Q

# WATER WELL REPORT
## STATE OF WASHINGTON

Application No. 31/01-11Q
Permit No.

**(1) OWNER:** Name R. L. Eggerman Address 757 So. Eggerman Rd. Coupeville, Wa. 98239

**(2) LOCATION OF WELL:** County Island ¼ SE ¼ Sec. 11 T. 31 N., R. 1E W.M.

Bearing and distance from section or subdivision corner 1570'W & 560'N FM SE 6R OF SEC 11

**(3) PROPOSED USE:** Domestic ☑ Industrial ☐ Municipal ☑ Irrigation ☐ Test Well ☐ Other ☐

**(4) TYPE OF WORK:** Owner's number of well (if more than one) 1
New well ☑ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☑ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

**(5) DIMENSIONS:** Diameter of well 6 inches.
Drilled 201 ft. Depth of completed well 201 ft.

**(6) CONSTRUCTION DETAILS:**

**Casing installed:** 6" Diam. from 0 ft. to 186 ft.
Threaded ☐ " Diam. from ft. to ft.
Welded ☑ " Diam. from ft. to ft.

**Perforations:** Yes ☐ No ☑
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

**Screens:** Yes ☑ No ☐
Manufacturer's Name Johnson
Type STAINLESS Model No.
Diam. 6 Slot size 14 from 186 ft. to 196 ft.
Diam. 6 Slot size 12 from 196 ft. to 201 ft.

**Gravel packed:** Yes ☐ No ☑ Size of gravel:
Gravel placed from ft. to ft.

**Surface seal:** Yes ☑ No ☐ To what depth? 18 ft.
Material used in seal CEMENT
Did any strata contain unusable water? Yes ☐ No ☑
Type of water? Depth of strata
Method of sealing strata off

**(7) PUMP:** Manufacturer's Name
Type: H.P.

**(8) WATER LEVELS:** Land-surface elevation above mean sea level 145 ft.
Static level 133'-4" ft. below top of well Date 7-20-75
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

**(9) WELL TESTS:** Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☒ No ☐ If yes, by whom? Bobs Pumps
Yield: 55 gal./min. with 3.5 ft. drawdown after 4 hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

| Time | Water Level | Time | Water Level | Time | Water Level |
|---|---|---|---|---|---|
| 1 min | 134'10" | | | | |
| 2 " | 134'-9" | | | | |
| 5 " | 133'-4" | | | | |

Date of test Aug 5, 1975
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes ☒ No ☐

**(10) WELL LOG:**

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

| MATERIAL | FROM | TO |
|---|---|---|
| SAND - DRY BROWN | 0 | 7 |
| GRAVELY HARD PAN | 7 | 25 |
| SAND - DRY | 25 | 132 |
| SANDY - HARD PAN | 132 | 160 |
| DIRTY WATER SAND | 160 | 184 |
| CLEAN WATER SAND | 184 | 201 |
| CLAY | 201 | |

NOTE:
WELL YEILDS 50 GPM or more.
(TEST PUMP TO be done at LATER DATE.)

(TEST made SEE #4)

Work started July 1975 Completed July 22, 1975

**WELL DRILLER'S STATEMENT:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WHIDBEY DRILLERS (Person, firm, or corporation) (Type or print)

Address OAK HARBOR WN

[Signed] Dennis Fabar (Well Driller)

License No. 0129 Date Oct, 1975

(USE ADDITIONAL SHEETS IF NECESSARY)

S. F. No. 7356—OS—(Rev. 4-71).