RECEIVED
MAR - 2 1994
DEPT. OF ECOLOGY

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Start Card No. 16650
UNIQUE WELL I.D. # ABD919
Water Right Permit No. 32/3E/27E

(1) OWNER: Name RALPH FERGUSEN Address XXXX RANCH RD.

(2) LOCATION OF WELL: County ISLAND SW 1/4 NW 1/4 Sec 27 T. 32 N., R. 3 W.M.

(2a) STREET ADDRESS OF WELL (or nearest address)

(3) PROPOSED USE: ☒ Domestic ☐ Irrigation ☐ DeWater Industrial ☐ Test Well ☐ Municipal ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one)
Abandoned ☐ New well ☒ Deepened ☐ Reconditioned ☐ Method: Dug ☐ Cable ☐ Rotary ☒ Bored ☐ Driven ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 182 feet. Depth of completed well 182 ft.

(6) CONSTRUCTION DETAILS:
Casing installed: 6" Diam. from +2 ft. to 172 ft.
Welded ☐ Liner installed ☐ Threaded ☐ " Diam. from ft. to ft.
" Diam. from ft. to ft.

Perforations: Yes ☐ No ☒
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes ☒ No ☐
Manufacturer's Name SMITH
Type SS Model No.
Diam 5 5/8 Slot size 25 from 172 ft. to 177 ft.
Diam 5 5/8 Slot size 18 from 177 ft. to 182 ft.

Gravel packed: Yes ☐ No ☒ Size of gravel
Gravel placed from ft. to ft.

Surface seal: Yes ☒ No ☐ To what depth? 18 ft.
Material used in seal BENTONITE
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name N/A
Type: H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level ft.
Static level 120 ft. below top of well Date 2-11-94
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☐ No ☐ If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test
Bailer test gal./min. with ft. drawdown after hrs.
Airtest 100+ gal./min. with stem set at 180 ft. for 2 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes ☒ No ☐

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
DIRT SAND & GRAVEL	0	5
HARD PAN	5	48
GREY CLAY	48	58
GREY CLAY W/SAND	58	64
SAND & SMALL GRAVEL	64	85
SAND	85	94
SAND & GRAVEL	94	165
SAND GRAVEL W/WATER	165	182

Work Started 2-10 94, 19. Completed 2-11, 1994

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME CAMANO WELL DRILLING (PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)
Address PO BOX 432 STANWOOD WA
(Signed) [signature] (WELL DRILLER) License No. 0611
Contractor's Registration No. CAMANWD 146R2 Date 2-14, 1994

(USE ADDITIONAL SHEETS IF NECESSARY)

ECL 050-1-20 (2/93) * * f

RECEIVED
MAR - 2 1994
DEPT. OF ECOLOGY

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Start Card No. 16650
UNIQUE WELL I.D. # ABD 919
Water Right Permit No. 32/3E/27E

(1) OWNER: Name RALPH FERGUSEN Address XXXX RANCH RD.

(2) LOCATION OF WELL: County ISLAND SW 1/4 NW 1/4 Sec 27 T. 32 N., R. 3 W.M.

(2a) STREET ADDRESS OF WELL (or nearest address)

(3) PROPOSED USE: ☒ Domestic ☐ Irrigation ☐ DeWater Industrial ☐ Test Well ☐ Municipal ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (If more than one)
Abandoned ☐ New well ☒ Deepened ☐ Reconditioned ☐ Method: Dug ☐ Cable ☐ Rotary ☒ Bored ☐ Driven ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 182 feet. Depth of completed well 182 ft.

(6) CONSTRUCTION DETAILS:
Casing Installed: 6 " Diam. from +2 ft. to 172 ft.
Welded ☐ " Diam. from ft. to ft.
Liner installed ☐ " Diam. from ft. to ft.
Threaded ☐

Perforations: Yes ☐ No ☒
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes ☒ No ☐
Manufacturer's Name SMITH
Type SS Model No.
Diam. 5 5/8 Slot size 25 from 172 ft. to 177 ft.
Diam. 5 5/8 Slot size 18 from 177 ft. to 182 ft.

Gravel packed: Yes ☐ No ☒ Size of gravel
Gravel placed from ft. to ft.

Surface seal: Yes ☒ No ☐ To what depth? 18 ft.
Material used in seal BENTONITE
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name N/A
Type: H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level ft.
Static level 120 ft. below top of well Date 2-11-94
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☐ No ☐ If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test
Bailer test gal./min. with ft. drawdown after hrs.
Airtest 100+ gal./min. with stem set at 180 ft. for 2 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes ☒ No ☐

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
DIRT SAND & GRAVEL	0	5
HARD PAN	5	48
GREY CLAY	48	58
GREY CLAY W/ SAND	58	64
SAND & SMALL GRAVEL	64	85
SAND	85	94
SAND & GRAVEL	94	165
SAND GRAVEL W/ WATER	165	182

Work Started 2-10 94, 19. Completed 2-11, 1994

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME CAMANO WELL DRILLING (PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)
Address PO BOX 432 STANWOOD WA
(Signed) [signature] (WELL DRILLER) License No. 0611
Contractor's Registration No. CAMANWD 146C2 Date 2-14, 1994

(USE ADDITIONAL SHEETS IF NECESSARY)

ECL 050-1-20 (2/93)