Copy with
Copy
Owner's Copy
Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Start Card No. N/11

UNIQUE WELL I.D. # 22888 D

Water Right Permit No. _____

(1) OWNER: Name Dave Bartl Address _____

(2) LOCATION OF WELL: County Island · S.W. 1/4 SE 1/4 Sec 30 T. 31N N. R. 03E W.M.

(2a) STREET ADDRESS OF WELL (or nearest address) 1994 S. Bartl Dr Camano Is. Washington 98282

(3) PROPOSED USE: ☐ Domestic ☐ Industrial ☐ Municipal ☐ ☐ Irrigation ☐ Test Well ☐ Other ☐ ☐ De-Watering

(4) TYPE OF WORK: Owner's number of well (if more than one) /

Abandoned ☐ New well ☐ Deepened ☐ Reconditioned ☐ Method: Dug ☐ Cable ☒ Rotary ☐ Bored ☐ Driven ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches. Drilled 160 feet. Depth of completed well 160 ft.

(6) CONSTRUCTION DETAILS:

Casing Installed: 6" Diam. from +2 ft. to 151 ft.
Welded ☒ " Diam. from ft. to ft.
Liner Installed ☐ Threaded ☐ " Diam. from ft. to ft.

Perforations: Yes ☐ No ☒
Type of perforator used _____
SIZE of perforations _____ in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

Screens: Yes ☒ No ☐
Manufacturer's Name Johnson
Type Stainless Model No. _____
Diam. 5 Slot size 15 from 150 ft. to 160 ft.
Diam. _____ Slot size _____ from _____ ft. to _____ ft.

Gravel packed: Yes ☐ No ☒ Size of gravel _____
Gravel placed from _____ ft. to _____ ft.

Surface seal: Yes ☐ No ☒ To what depth? _____ ft.
Material used in seal _____
Did any strata contain unusable water? Yes ☐ No ☐
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(7) PUMP: Manufacturer's Name N/A
Type: _____ H.P. _____

(8) WATER LEVELS: Land-surface elevation above mean sea level Approx 120' ft.
Static level 120 ft. below top of well Date 10/14/68
Artesian pressure _____ lbs. per square inch Date _____
Artesian water is controlled by _____ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☒ No ☐ If yes, by whom? Driller
Yield: 100 gal./min. with 7 ft. drawdown after 4 hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test 10/14/68
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Airtest _____ gal./min. with stem set at _____ ft. for _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes ☐ No ☐

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
sandy clay	0	20
dry sand	20	75
yellow clay	75	80
dry coarse sand	80	90
dry gravel	90	115
yellow clay	115	125
sand & water	125	160

Work Started 10/14/68, 19. Completed 10/14/68, 19

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME A.G. Kounkel Well Drilling (PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)

Address 7971 N. Smith Rd. Camano Is. Wa

(Signed) Larry Kounkel (WELL DRILLER) License No. 1892

Contractor's Registration No. KOUNKWD899KT Date 6/11, 19 94

(USE ADDITIONAL SHEETS IF NECESSARY)

ECL 050-1-20 (2/93)