30-3E-10 R

WATER WELL REPORT

Original & 1st copy – Ecology, 2nd copy – owner, 3rd copy – driller

Construction/Decommission ("x" in circle) 200736

☒ Construction

○ Decommission *ORIGINAL INSTALLATION Notice of Intent Number* _____

CURRENT
Notice of Intent No. W098090

Unique Ecology Well ID Tag No. AFJ 760

Water Right Permit No. GT 25111 C

Property Owner Name Camano Vista Water Dist.

Well Street Address _____

City Camano Isl. County Island

Location SE 1/4-1/4 SE 1/4 Sec 10 Twn 30 R 3E EWM or WWM (circle one)

Lat/Long (s, t, r Still **REQUIRED**) Lat Deg _____ Lat Min/Sec _____ Long Deg _____ Long Min/Sec _____

Tax Parcel No. _____

PROPOSED USE: ☐ Domestic ☐ Industrial ☒ Municipal ☐ DeWater ☐ Irrigation ☐ Test Well ☐ Other _____

TYPE OF WORK: Owner's number of well (if more than one) _____

☒ New well ☐ Reconditioned ☐ Deepened

Method: ☐ Dug ☐ Bored ☐ Driven ☒ Cable ☐ Rotary ☐ Jetted

DIMENSIONS: Diameter of well 6 inches, drilled 197 ft.
Depth of completed well 182 ft.

CONSTRUCTION DETAILS

Casing Installed: ☒ Welded 6" Diam. from +2 ft. to 174 ft.
☐ Liner installed _____" Diam. from _____ ft. to _____ ft.
☐ Threaded _____" Diam. from _____ ft. to _____ ft.

Perforations: ☐ Yes ☒ No

Type of perforator used _____

SIZE of perfs _____ in. by _____ in. and no. of perfs ____ from ____ ft. to ____ ft.

Screens: ☒ Yes ☐ No ☐ K-Pac Location 171

Manufacturer's Name Alloy

Type S. Steel Model No. _____

Diam. 5 Slot size 4 from 172 ft. to 182 ft.

Diam. _____ Slot size _____ from _____ ft. to _____ ft.

Gravel/Filter packed: ☐ Yes ☒ No ☐ Size of gravel/sand _____

Materials placed from _____ ft. to _____ ft.

Surface Seal: ☒ Yes ☐ No To what depth? 36 ft.

Material used in seal BENONITE

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? _____ Depth of strata _____

Method of sealing strata off _____

PUMP: Manufacturer's Name Gould's

Type: SUB H.P. 1 1/2

WATER LEVELS: Land-surface elevation above mean sea level _____ ft.

Static level 168-7 ft. below top of well Date 5/8/06

Artesian pressure _____ lbs. per square inch Date _____

Artesian water is controlled by _____ (cap, valve, etc.)

WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? ☒ Yes ☐ No If yes, by whom? GENE'S

Yield: 5 gal./min. with 11 ft. drawdown after 8 hrs.

Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.

Yield. _____ gal./min. with _____ ft. drawdown after _____ hrs.

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test _____

Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.

Airtest _____ gal./min. with stem set at _____ ft. for _____ hrs.

Artesian flow _____ g.p.m. Date _____

Temperature of water _____ Was a chemical analysis made? ☒ Yes ☐ No

CONSTRUCTION OR DECOMMISSION PROCEDURE

Formation: Describe by color, character, size of material and structure, and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information. (USE ADDITIONAL SHEETS IF NECESSARY.)

MATERIAL	FROM	TO
Top-soil	0	2
sandy-clay	2	26
Dry sand-gravel	26	178
water sand	178	181
Blue clay	181	197
Well siting per Island Co. code 8.09.07 C-D&E		

RECEIVED JUN 23 2006 DEPT. OF ECOLOGY

Start Date 4/10/06 Completed Date 5/8/06

WELL CONSTRUCTION CERTIFICATION: I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

☒ Driller ☐ Engineer ☐ Trainee Name (Print) GENE HITT

Driller/Engineer/Trainee Signature Gene Hitt

Driller or trainee License No. 0186

Drilling Company GENE'S Well Drilling

Address 5115 268TH ST. N.W

City, State, Zip STANWOOD, WA 98292

Contractor's Registration No. GENESWD071CC Date 5/15/06

If TRAINEE,
Driller's Licensed No. _____
Driller's Signature _____

Ecology is an Equal Opportunity Employer.

ECY 050-1-20 (Rev 3/05)

The Department of Ecology does NOT warranty the Data and/or Information on this Well Report.

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.