The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

(4)

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT
STATE OF WASHINGTON

Application No. .....
Permit No. .....

(1) OWNER: Name DICK GLEASON, Address

(2) LOCATION OF WELL: County ISLAND SE ¼ SW ¼ Sec. 34 T. 30 N., R. 2 W.M.

Bearing and distance from section or subdivision corner 1520' From SEC 33 + 300' From SEC 3

(3) PROPOSED USE: Domestic ☐ Industrial ☐ Municipal ☐ Irrigation ☐ Test Well ☐ Other ☒

(4) TYPE OF WORK: Owner's number of well (if more than one)....
New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☐ Driven ☐
Reconditioned ☐ Rotary ☒ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 340 ft. Depth of completed well 332 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6" Diam. from 0 ft. to 317 ft.
Threaded ☐ ..... " Diam. from ..... ft. to ..... ft.
Welded ☒ ..... " Diam. from ..... ft. to ..... ft.

Perforations: Yes ☐ No ☒
Type of perforator used .....
SIZE of perforations ..... in. by ..... in.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.

Screens: Yes ☒ No ☐
Manufacturer's Name JOHNSON
Type CONTINUOUS WELD S-2 Model No. .....
Diam. 5 Slot size 4 from 316 ft. to 321 ft.
Diam. 5 Slot size 8 from 321 ft. to 326 ft.
10 326 332

Gravel packed: Yes ☐ No ☒ Size of gravel: .....
Gravel placed from ..... ft. to ..... ft.

Surface seal: Yes ☒ No ☐ To what depth? 20 ft.
Material used in seal BENTONITE.
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? ..... Depth of strata .....
Method of sealing strata off .....

(7) PUMP: Manufacturer's Name .....
Type: ..... H.P. .....

(8) WATER LEVELS: Land-surface elevation above mean sea level.... ..... ft.
Static level ..... ft. below top of well Date .....
Artesian pressure ..... lbs. per square inch Date .....
Artesian water is controlled by ..... (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☐ No ☐ If yes, by whom? .....
Yield: ..... gal./min. with ..... ft. drawdown after ..... hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test .....
Bailer test ..... gal./min. with ..... ft. drawdown after ..... hrs.
Artesian flow ..... g.p.m. Date .....
Temperature of water ..... Was a chemical analysis made? Yes ☐ No ☐

(10) WELL LOG:

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
BROWN GRAVELY SILT.	0	14
GRAY CLAY.	14	86
GRAY COMPACT SILTY GRAVEL	86	112
GRAY SILTY FINE SAND.	112	118
GRAY SILTY CLAY.	118	177
GRAY FINE SAND AND SILTY GRAVEL	177	188
GRAY SILTY CLAY.	188	271
GRAY SILTY FINE SAND.	271	283
GRAY SILTY FINE TO MEDIAM SAND.	283	288
GRAY SILTY CLAY.	288	302
GRAY MEDIAM TO CORASE SAND WITH GRAVEL.	302	328
GRAY FINE TO MEDIAM SAND.	328	340

WELL No. 4

Work started SEP 7 1984 Completed SEP 19 1984

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME B + W DRILLING. (Person, firm, or corporation) (Type or print)

Address .....

[Signed] ..... (Well Driller)

License No. ..... Date ....., 19....

(USE ADDITIONAL SHEETS IF NECESSARY)