WELL DRILLING
ADVISORY SERVICE
WELL TESTING

JAMES L. BELL
WATER WELL
DRILLING
FORMERLY JAMES J. BELL & SON EST. 1936

ROUTE 1, BOX 140H
FREELAND, WASHINGTON
98249

PHONE: EV. 2-5701

August 13, 1960

Lakeside Bible Camp Association, Inc.
Mr. L. Heitz
7557 45th N. E.
Seattle, Washington

Well Log for Bible Camp Well--Deer Lake

0	-	1	Top soil
1	-	6	Brown sand
6	-	65	Brown semi hardpan
65	-	90	Sand & gravel, small amount of clay. Water at 90'.
90	-	112	Brown clay
112	-	120	Brown hardpan
120	-	142	Cemented gravel, water bearing

10' of Johnson Red Brass No. 15 slot well screen.
4" bail-down nipple with 6'5" of 5" pipe on top of screen.
Pumped 25 G.P.M. at 132'
Small trace of sand pumping 25 G.P.M. Would advise not pumping over 20 G.P.M.

Time	Minutes	Drawdown	G.P.M.	Time for 5 Gal.
7:50	0	105-8	10	30 sec.
8:45	15	110-9	10	30 sec.
9:00	15	111-1	10	30 sec.
9:15	15	111-2	10	30 sec.
9:30	15	112-4	15	20 sec.
9:30	15	112-6	15	20 sec.
9:45	15	112-7	15	20 sec.
10:00	15	112-7½	15	20 sec.
10:15	15	112-8	15	20 sec.
10:30	15	112-9	15	20 sec.
10:45	15	112-9	15	20 sec.
11:00	15	112-9	15	20 sec.

Recovery time 106-1 in five minutes
106 in thirty minutes