First Copy with
ecology
Owner's Copy
Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Application No. .....

Permit No. .....

ER: Name Baker View Terrace Water Co. Address Camano Is.

ATION OF WELL: County ISLAND — ¼ ¼ Sec. T. N., R. W.M.

nd distance from section or subdivision corner

OPOSED USE: Domestic ☒ Industrial ☐ Municipal ☐ Irrigation ☐ Test Well ☐ Other ☐

TYPE OF WORK: Owner's number of well (if more than one) ....

New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☒ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 280 ft. Depth of completed well 280 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6 " Diam. from 0 ft. to 270 ft.
Threaded ☐ ..... " Diam. from ..... ft. to ..... ft.
Welded ☒ ..... " Diam. from ..... ft. to ..... ft.

Perforations: Yes ☒ No ☐
Type of perforator used Mills
SIZE of perforations 1½ in. by ⅜ in.
8 perforations from 92 ft. to 94 ft.
8 perforations from 94 ft. to 96 ft.
8 perforations from 98 ft. to 101 ft.

Screens: Yes ☐ No ☒
Manufacturer's Name .....
Type ..... Model No. .....
Diam. ..... Slot size ..... from ..... ft. to ..... ft.
Diam. ..... Slot size ..... from ..... ft. to ..... ft.

Gravel packed: Yes ☐ No ☒ Size of gravel: .....
Gravel placed from ..... ft. to ..... ft.

Surface seal: Yes ☒ No ☐ To what depth? 18 ft.
Material used in seal Bentonite & CLAY
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? ..... Depth of strata .....
Method of sealing strata off .....

(7) PUMP: Manufacturer's Name .....
Type: ..... H.P. .....

(8) WATER LEVELS: Land-surface elevation above mean sea level .... 110 ft.
Static level 90 ft. below top of well Date 6/6/62
Artesian pressure ..... lbs. per square inch Date .....
Artesian water is controlled by ..... (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☒ No ☐ If yes, by whom? Driller
Yield: 25 gal./min. with 1½ ft. drawdown after 4 hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level
1:15	91½	1:45	90'	2:30	90'
1:25	90½	1:55	90'	3:00	90'
1:35	90'	2:05	90'	3:30	90'

Date of test 6/6/62
Bailer test 20 gal./min. with 0 ft. drawdown after 3 hrs.
Artesian flow ..... g.p.m. Date .....
Temperature of water 51° Was a chemical analysis made? Yes ☒ No ☐

(10) WELL LOG:

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
TOPSOIL	0	5
GRAVEL	5	12
DRY SAND	12	92
PEA GRAVEL & WATER	92	103
DRY BLUE CLAY	103	280?

SWL 90'

92 open

Work started June 11, 1962 Completed July 6, 1962

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Kunkel Well Drilling (Person, firm, or corporation) (Type or print)

Address 797 N. Smith RD. Camano Is.

[Signed] A. G. Kunkel (Well Driller)

License No. 987 Date Feb 17, 1989

(USE ADDITIONAL SHEETS IF NECESSARY)

ECY 050-1-20