The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

...and First Copy with ... of Ecology
...Copy—Owner's Copy
...Copy—Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Start Card No. R32803-181-0750

Water Right Permit No. PWSID 33251

(1) OWNER: Name Paul KOLOSET Address Dalton Realty

(2) LOCATION OF WELL: County Island NW ¼ SW ¼ Sec 3 T 28 N., R 03 E W.M.

(2a) STREET ADDDRESS OF WELL (or nearest address) 7475 S. Bailey Rd Clinton 98236

(3) PROPOSED USE: [X] Domestic [ ] Irrigation [ ] DeWater [ ] Industrial [ ] Test Well [ ] Municipal [ ] Other

(4) TYPE OF WORK: Owner's number of well (if more than one)
Abandoned [ ] New well [X] Deepened [ ] Reconditioned [ ]
Method: Dug [ ] Cable [ ] Rotary [X] Bored [ ] Driven [ ] Jetted [ ]

(5) DIMENSIONS: Diameter of well 6" inches.
Drilled 115 feet. Depth of completed well 112 ft.

(6) CONSTRUCTION DETAILS:
Casing installed: 6" Diam. from 0 ft. to 103' ft.
Welded [X] " Diam. from ft. to ft.
Liner installed [ ] " Diam. from ft. to ft.
Threaded [ ]

Perforations: Yes [ ] No [X]
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes [X] No [ ]
Manufacturer's Name COOK
Type Stainless Steel Model No.
Diam. 6" Slot size 8 from 102 ft. to 107 ft.
Diam. 6" Slot size 10 from 107 ft. to 112 ft.

Gravel packed: Yes [ ] No [X] Size of gravel
Gravel placed from ft. to ft.

Surface seal: Yes [X] No [ ] To what depth? 20 ft.
Material used in seal Bentonite
Did any strata contain unusable water? Yes [ ] No [X]
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name STA-RITE
Type: Submersible H.P. 1½

(8) WATER LEVELS: Land-surface elevation above mean sea level 120 ft.
Static level 69' ft. below top of well Date 8-10-91
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes [ ] No [X] If yes, by whom?
Yield: 30 gal./min. with 20 ft. drawdown after 1 hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test
Bailer test gal./min. with ft. drawdown after hrs.
Airtest gal./min. with stem set at ft. for hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes [ ] No [ ]

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
SAND + CLAY	0	8
CLAY + Fine SAND	8	32
HARD PAN Gray	32	85
Fine Sand Gray	85	100
Brown Sand W.W.	100	115

RECEIVED
MAR 14 2008
DEPT. OF ECOLOGY

Work started 8-1-91, 19. Completed 8-10-91, 19.

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME B + W Drilling (PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)
Address 4087 E. Deer Lake Rd. Clinton
(Signed) [signature] (WELL DRILLER) License No. 264
Contractor's Registration No. Date 8-11-91

(USE ADDITIONAL SHEETS IF NECESSARY)

050-1-20 (10/87) -1329-

475.0712225071 3 (m) Albatross