ENTERED

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Start Card No. W072775
UNIQUE WELL I.D. #
Water Right Permit No. 29-3E-11 H

(1) OWNER: Name KENDN SIMMONS Address P.O. 577 CLINTON WA 98236

(2) LOCATION OF WELL: County ISLAND · SE 1/4 NE 1/4 Sec 11 T. 29 N., R. 3E W.M.

(2a) STREET ADDRESS OF WELL (or nearest address) 10 A. WILKENSON RD. TRACTS LANGLEY WA.

(3) PROPOSED USE: [X] Domestic [ ] Irrigation [ ] DeWater Industrial [ ] Test Well [ ] Municipal [ ] Other [ ]

(4) TYPE OF WORK: Owner's number of well (If more than one) 1
Abandoned [ ] New well [X] Deepened [ ] Reconditioned [ ]
Method: Dug [ ] Cable [X] Rotary [ ] Bored [ ] Driven [ ] Jetted [ ]

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 106 feet. Depth of completed well 106 ft.

(6) CONSTRUCTION DETAILS:
Casing Installed: 6" Diam. from 0 ft. to 101 ft.
Welded [X] " Diam. from ft. to ft.
Liner installed [ ] Threaded [ ] " Diam. from ft. to ft.

Perforations: Yes [ ] No [X]
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes [X] No [ ]
Manufacturer's Name COOK
Type STAINLESS Model No.
Diam. 6 Slot size 10 from 101 ft. to 106 ft.
Diam. Slot size from ft. to ft.

Gravel packed: Yes [ ] No [X] Size of gravel
Gravel placed from ft. to ft.

Surface seal: Yes [X] No [ ] To what depth? 20 ft.
Material used in seal BENTONITE
Did any strata contain unusable water? Yes [ ] No [X]
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name
Type: H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level 170 ft.
Static level 81' ft. below top of well Date 8-97
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes [ ] No [X] If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test
Bailer test 15 gal./min. with MAX ft. drawdown after 3 hrs.
Airtest gal./min. with stem set at ft. for hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes [ ] No [X]

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
HARD COMPACT SAND	0	35
MOSTLY SAND	35	90
WATER SAND (FINE)	90	106
SANDY CLAY	106	

RECEIVED
AUG 20 1997
DEPT. OF ECOLOGY

Work Started Aug 7, 19 97 Completed Aug 8, 19 97

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME WHIDBEY DRILLERS (PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)
Address OAK HARBOR WA
(Signed) [signature] (WELL DRILLER) License No. 129
Contractor's Registration No. WHID289MM Date Aug 8, 19 97

(USE ADDITIONAL SHEETS IF NECESSARY)

Ecology is an Equal Opportunity and Affirmative Action employer. For special accommodation needs, contact the Water Resources Program at (206) 407-6600. The TDD number is (206) 407-6006.

ECY 050-1-20 (9/93) * * I