File Original and First Copy with Department of Ecology
Second Copy—Owner's Copy
Third Copy—Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Start Card No. _____

Water Right Permit No. 8695

(1) OWNER: Name Wilbur Ginn Water Co Address _____

(2) LOCATION OF WELL: County Island _____ ¼ ¼ Sec 26 T 30 N., R 5 W.M.

(2a) STREET ADDDRESS OF WELL (or nearest address) 4116

(3) PROPOSED USE: [X] Domestic [ ] Irrigation [ ] DeWater Industrial [ ] Test Well [ ] Municipal [ ] Other [ ]

(4) TYPE OF WORK: Owner's number of well (if more than one) _____
Abandoned [ ] New well [X] Deepened [ ] Reconditioned [ ] Method: Dug [X] Cable [ ] Rotary [ ] Bored [ ] Driven [ ] Jetted [ ]

(5) DIMENSIONS: Diameter of well 36 inches
Drilled 17 feet. Depth of completed well 17 ft.

(6) CONSTRUCTION DETAILS:
Casing Installed: _____ " Diam. from 0 ft. to 17 ft.
Welded [ ] _____ " Diam. from _____ ft. to _____ ft.
Liner installed [ ]
Threaded [ ] _____ " Diam. from _____ ft. to _____ ft.

Perforations: Yes [ ] No [ ]
Type of perforator used _____
SIZE of perforations _____ in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from 15 ft. to 17 ft.

Screens: Yes [X] No [ ]
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ from _____ ft. to _____ ft.
Diam. _____ Slot size _____ from _____ ft. to _____ ft.

Gravel packed: Yes [X] No [ ] Size of gravel _____
Gravel placed from _____ ft. to _____ ft.

Surface seal: Yes [X] No [ ] To what depth? _____ ft.
Material used in seal Cement
Did any strata contain unusable water? Yes [ ] No [X]
Type of water? _____ Depth of strata _____
Method of sealing strata off Cement

(7) PUMP: Manufacturer's Name _____
Type _____ H.P. _____

(8) WATER LEVELS: Land-surface elevation above mean sea level 90 ft.
Static level 12 ft. below top of well Date _____
Artesian pressure _____ lbs. per square inch Date _____
Artesian water is controlled by _____ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes [X] No [ ] If yes, by whom? T Snowden
Yield: 350 gal./min. with 0 ft. drawdown after 2 hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test _____
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Airtest _____ gal./min. with stem set at _____ ft. for _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes [ ] No [ ]

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
Clay	0	12
gravel	12	17

Work started _____, 19__. Completed _____, 19__

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME SNOWDEN Well Digging (PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)

Address 3225 SE Camano Dr.

(Signed) Theodore R Snowden (WELL DRILLER) License No. _____

Contractor's Registration No. 0464 Date May 10, 1974

(USE ADDITIONAL SHEETS IF NECESSARY)

ECY 050-1-20 (10/87) -1329 3

Reproduced 1991 due to loss of file data