File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy 28/3E/08/A

WATER WELL REPORT

STATE OF WASHINGTON

Application No. 28/03-08A

Permit No. ....

(1) OWNER: Name RICKETTS BUD Address CLINTON WASH 98236

(2) LOCATION OF WELL: County ISLAND — NE¼ NE¼ Sec. 8 T. 28 N., R. 3 W.M.

Bearing and distance from section or subdivision corner 260' SOUTH & 100' WEST OF NE CORNER

(3) PROPOSED USE: Domestic ☒ Industrial ☐ Municipal ☐ Irrigation ☒ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) ....

New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☒ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 29 ft. Depth of completed well 29 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6" Diam. from 0 ft. to 24 ft.
Threaded ☐ " Diam. from ft. to ft.
Welded ☒ " Diam. from ft. to ft.

Perforations: Yes ☐ No ☒
Type of perforator used ....
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes ☒ No ☐
Manufacturer's Name LOOK
Type S.S. Model No. ....
Diam. 6 Slot size 12 from 24 ft. to 29 ft.
Diam. Slot size from ft. to ft.

Gravel packed: Yes ☐ No ☒ Size of gravel: ....
Gravel placed from ft. to ft.

Surface seal: Yes ☒ No ☐ To what depth? 18 ft.
Material used in seal BENTONITE
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name STA RITE
Type: SUB H.P. ½

(8) WATER LEVELS: Land-surface elevation above mean sea level .... 10 ft.
Static level 7 ft. below top of well Date 8-24
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☒ No ☐ If yes, by whom? DRILLER
Yield: 12 gal./min. with 25 ft. drawdown after 1 hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes ☐ No ☒

(10) WELL LOG:

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
TOP SOIL	0	2'
SANDY CLAY (MUD) BLUE	2'	5'
WW SAND BROWN	5'	6'
WW CLAY WITH SAND GRAY	6'	12'
WW COARSE SAND GRAY	12'	29'
WW FINE SAND BROWN	29	

Work started 8-6, 1974. Completed 8-9, 1974

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME B & W DRILLING CO (Person, firm, or corporation) (Type or print)

Address P.O. BOX 55 FREELAND WA 98249

[Signed] [signature] (Well Driller)

License No. 263-264 Date 12-9, 1974

(USE ADDITIONAL SHEETS IF NECESSARY)

S. F. No. 7356—OS—(Rev. 4-71).

RECEIVED
DEC 13 '74