File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

31/01-14 J
Application No

Permit No.

(1) OWNER: Name City of Coupeville Address 4 Seventh Street PO. 725 Cup. 98239

(2) LOCATION OF WELL: County Island - Hamton tract - Lot 5 NE ¼ SE ¼ Sec. 14 T. 31 N., R. 1 E. W.M.

Bearing and distance from section or subdivision corner from Meadows

(3) PROPOSED USE: Domestic ☐ Industrial ☐ Municipal ☒ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) #3

New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☒ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 12 inches.
Drilled 114 ft. Depth of completed well 69 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6 " Diam. from 0 ft. to 53 ft.
Threaded ☐ " Diam. from 58 ft. to 63 ft.
Welded ☐ " Diam. from ft. to ft.

Perforations: Yes ☐ No ☒
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes ☒ No ☐ Cook
Manufacturer's Name
Type 304 Stainless Model No.
Diam. 6 Slot size 10 from 53 ft. to 58 ft.
Diam. Slot size from ft. to ft.

Gravel packed: Yes ☒ No ☐ Size of gravel: Aqua #8
Gravel placed from 63.5 ft. to 33 ft.

Surface seal: Yes ☒ No ☐ To what depth? 33 ft.
Material used in seal Cement Grout
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name
Type: H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level ft.
Static level 28 ft. below top of well Date
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☒ No ☐ If yes, by whom?
Yield: 8 gal./min. with 15 ft. drawdown after 4 hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes ☐ No ☐

(10) WELL LOG:

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
topsoil	0	2
sand some gravel	2	6
tan clay	6	12
Brown sand	12	46
Gray sand some silts	46	67
Gray silty gravel + cobbles	67	81
Fill	81	97
gray sand	97	100
Sand + gravel layered with silt	100	114

Work started 1-12, 19 87 Completed 3-20, 19 87

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Holt Drilling Inc. (Person, firm, or corporation) (Type or print)

Address 1255 22nd Street East

[Signed] Randy Holt (Well Driller)

License No. 1099 Date 4-10-87, 19

(USE ADDITIONAL SHEETS IF NECESSARY)

ECY 050-1-20